

# Acoustical comments

Page: [Policy D13 Noise](#)

Section: [3.13.3](#)

More recent and comprehensive Good Acoustic Design (GAD) guidance has been produced by a working group from the Institute of Acoustics, Association of Noise Consultants, and the Chartered Institute of Environmental Health titled ProPG: Planning and Noise. This uses BS8233 as a basis but relates GAD to other adverse impacts such as overheating and thermal comfort from sealed facade designs.