

# My comments

Page: [Policy D11 Fire safety](#)

Section: [D11](#)

We should state more than just the highets standards, the exact standard should be stipulated, i.e. constructed in accordance with approved document B by a FIRAS registered contractor.

Page: [Policy D11 Fire safety](#)

Section: [3.11.5](#)

It is important to state both the type and manufacturer of the used material, not just the propoesed material.

These should be assessed for compatability within the overall structure and all the effects one particular product may have upon another when used side by side.

The strength of a system approach is very important.