

Revised Energy Strategy

(Full Planning Application Submission)

For

Kidbrooke Station Square

On behalf of:

Kidbrooke Partnership LLP

Date October 2019

Reference G39/K180038/CH

Rev Rev 08

King's Head House King's Head Yard Borough High Street London SE1 1NA020 7940 32
london@calfordseaden.co.uk

calfordseaden.com

ORPINGTON | LONDON | BIRMINGHAM | SOUTHEND-ON-SEA | WINCHESTER | CAMBRIDGE

calfordseaden LLP is a Limited Liability Partnership Registered in England and Wales number OC315838.

Registered Office: Devonshire House 60 Goswell Road London EC1M 7AD where a list of members is kept

Regulated by RICS

TABLE OF CONTENTS

| | | |
|-----------|---|-----------|
| 1 | Executive Summary | 4 |
| 1.1 | Description of Development | 4 |
| 1.2 | Relevant Planning Policies..... | 4 |
| 2 | Introduction | 5 |
| 3 | Policy Guidance & Project Strategy | 6 |
| 3.1 | Energy Strategy measures checklist: | 9 |
| 4 | Baseline Emissions | 11 |
| 4.1 | Part L 2013 Baseline Emissions | 11 |
| 4.2 | Baseline emissions..... | 11 |
| 5 | Proposed Be Lean Enhancements | 13 |
| 6 | Proposed Be Clean Enhancements | 17 |
| 6.1 | Connection to existing heating or cooling networks..... | 17 |
| 6.2 | Site-wide Network..... | 19 |
| 7 | Proposed ‘Be Green’ Enhancements | 22 |
| 7.1 | General | 29 |
| 7.2 | Air Source Heat Pumps..... | 29 |
| 7.3 | Heat Distribution Losses..... | 34 |
| 7.4 | Photovoltaic Panels | 36 |
| 7.5 | Be Green Summary..... | 36 |
| 8 | BREEAM | 39 |
| 9 | Overheating | 42 |
| 9.1 | Overheating Checklist..... | 44 |
| 10 | London Zero Carbon Homes | 48 |
| 11 | Conclusion | 50 |
| 11.1 | Overall CO ₂ emissions..... | 50 |
| 12 | Appendices | 51 |

Revision Note

| REVISION | | |
|----------|----------|--------------------------------------|
| Rev. | Date: | Description |
| 01 | 26/10/18 | First Draft |
| 02 | 09/11/18 | Second Draft |
| 03 | 15/11/18 | Full Planning Application Submission |
| 04 | 19/11/18 | Full Planning Application Submission |
| 05 | 29/01/19 | GLA Comments |
| 06 | 28/08/19 | Air Source Heat Pumps replaced CHP |
| 07 | 08/10/19 | Incorporation of DLF - Draft |
| 08 | 14/10/19 | Final Issue |

St John's House 1a Knoll Rise Orpington Kent BR6 0JX

01689 888 222 orpington@calfordseaden.co.uk

calfordseaden.co.uk

ORPINGTON | LONDON | BIRMINGHAM | SOUTHEND-ON-SEA | WINCHESTER | CAMBRIDGE

calfordseaden LLP is a Limited Liability Partnership Registered in England and Wales number OC315838.

Registered Office: Devonshire House 60 Goswell Road London EC1M 7AD where a list of members is kept

Regulated by RICS

1 EXECUTIVE SUMMARY

This energy strategy has been prepared on behalf of Kidbrooke Partnership LLP in support of full planning application for the comprehensive redevelopment of Kidbrooke Station Square site, Greenwich. This document details the energy efficient measures and technologies proposed in order to meet the London plan and Royal Borough of Greenwich requirements.

The energy statement follows the Be Lean, Be Clean, Be Green framework described by the London Plan 2019.

The original Energy Strategy for the development proposed the usage of a Combined Heat and Power (CHP) engine in order to achieve the CO2 reductions of the development in line with the London Plan 2016 hierarchy.

Since January 2019 the GLA encourage the use on the SAP10 emissions factors and the SAP10 calculation spreadsheet, with consultation with the GLA it has been decided that the amended Energy Strategy for the Kidbrooke Station Square development will incorporate this guidance and as a result of that the CHP has been replaced with Air Source Heat Pumps (ASHPs).

In this report it will be demonstrated the reduction of the CO2 emissions with the revised emission factors and provide supporting calculations how the ASHP will achieve the specified average yearly efficiency in supplying the required annual heat load percentage of the development.

This change will ensure that the calculations for the reduction of the CO2 emissions is in line with the current emission factors and hence better reflects the actual carbon emissions associated with the expected operation

1.1 Description of Development

A comprehensive development comprising 619 residential dwellings (Class C3 use), retail use (Class A1/A3 uses), business use (Class B1 use), a nursery (Class D1 use), new station and residential squares and other public realm, hard and soft landscaping, highways works including bus stop provision, parking, access and servicing arrangements, plant and associated works.

1.2 Relevant Planning Policies

It is the developer's intention for the proposed development that;

- The development will be designed and constructed to meet the London Plan 2019, through a combination of energy conservation measures, low carbon technologies, and exploring renewable technologies considering the site particulars.
- The development will comply with Royal Greenwich Local Plan: Core Strategy with Detailed Policies (2014)
- The non-residential spaces will be designed to achieve high scoring BREEAM "Very Good", proposed reduction on policy which states "Excellent". Refer to section 8 for justification.

2 INTRODUCTION

This report will investigate the various options for provision of low carbon and renewable technologies on behalf of Kidbrooke Partnership LLP in relation to the development at Kidbrooke Station Square. This report will discuss the most appropriate options available in order to offset a proportion of the total predicted energy loads of the development using passive measures, low carbon and renewable energy technologies.

This report will demonstrate how the development proposals make the fullest contribution to minimising carbon dioxide emissions in accordance with the following energy hierarchy:

1. Be lean: use less energy
2. Be clean: supply energy efficiently
3. Be green: use renewable energy

Target emissions are expressed as minimum improvements over the Target Emission Rate (TER) outlined in the national Building Regulations 2013 Part L.

At the request of GLA the SAP10 calculations have also been used for the production of this report. As the SAP2012 do not take into account the planned decarbonisation of the electricity grid, SAP10 has been used for the calculations

3 POLICY GUIDANCE & PROJECT STRATEGY

LB Greenwich Policies

Housing

POLICY H5

New residential development, redevelopment, refurbishment or conversions will be expected to achieve a high quality of housing design and an integrated environment. The Royal Borough will take into account the key relationships between the character of the area, site location and housing densities and expect the following:

- i. For new build homes, the achievement of Code for Sustainable Homes of at least code level four (4);**
- ii. The design of the development is consistent with Policy DH1 and, for all new build housing developments, is also consistent with the Mayor of London's Housing SPG;*
- iii. An acceptable level of noise insulation being achieved by means of sensitive design, layout and in developments vulnerable to transportation noise and vibration;*
- iv. A presumption against single-aspect north facing units and a presumption in favour of dual aspect units where possible;*
- v. In flats, a good-sized balcony, a terrace or enclosed communal gardens should be provided;*
- vi. Family housing should normally have direct access to a private garden. Schemes with predominantly family housing should, as far as practicable, be within reasonable walking distance of nursery and primary schools, local shops, play areas and amenities;*
- vii. Safety and security of residents and public (see also Policy CH1);*
- viii. The provision of new housing to Lifetime Homes standards;*
- ix. In residential developments of 25 or more units, 10% of dwellings to be built to full wheelchair standard, or easily adaptable for residents who are wheelchair users;*
- x. New build developments of flats that are three or more storeys will be required to have sufficient lifts;*

Climate Change Mitigation

POLICY E 1 Carbon Emissions

Carbon emissions will be reduced in accordance with the Mayor's energy hierarchy by:

- i. First, requiring all development to reduce demand for energy through its design (Be Lean);*
- ii. Second, requiring all developments, with a gross floor area greater than 500sqm, or residential developments of five or more units, to connect to an existing decentralised energy network. Where this is not available a site wide decentralised energy network is required. Where it is demonstrated that a site wide decentralised energy network is unfeasible and / or unviable, developments will be required to provide sufficient infrastructure to enable a connection to a decentralised energy network for immediate or future use (Be Clean);*
- iii. Third, supporting the incorporation of renewable energy generation within development proposals (Be Green).*

All major development proposals will require an energy assessment.

London Plan 2016

POLICY 5.2: Minimising Carbon Dioxide Emissions

- A. Development proposals should make the fullest contribution to minimising carbon dioxide emissions in accordance with the following energy hierarchy:
1. Be lean: use less energy
 2. Be clean: supply energy efficiently
 3. Be green: use renewable energy
- B. The Mayor will work with boroughs and developers to ensure that major developments meet the following targets for carbon dioxide emissions reduction in buildings. These targets are expressed as minimum improvements over the Target Emission Rate (TER) outlined in the national Building Regulations leading to zero carbon residential buildings from 2016 and zero carbon non-domestic buildings from 2019.

Residential buildings

| Year | Improvement on 2013 Building Regulations |
|-------------|--|
| 2016 – 2031 | Zero Carbon |

Non-domestic buildings

| Year | Improvement on 2013 Building Regulations |
|-------------|--|
| 2016 – 2031 | 35% |

- C. Major development proposals should include a detailed energy assessment to demonstrate how the targets for carbon dioxide emissions reduction outlined above are to be met within the framework of the energy hierarchy.
- D. As a minimum, energy assessments should include the following details:
- a. calculation of the energy demand and carbon dioxide emissions covered by Building Regulations and, separately, the energy demand and carbon dioxide emissions from any other part of the development, including plant or equipment, that are not covered by the Building Regulations (see paragraph 5.22) at each stage of the energy hierarchy
 - b. proposals to reduce carbon dioxide emissions through the energy efficient design of the site, buildings and services
 - c. proposals to further reduce carbon dioxide emissions through the use of decentralised energy where feasible, such as district heating and cooling and combined heat and power (CHP)
 - d. proposals to further reduce carbon dioxide emissions through the use of on-site renewable energy technologies.
- E. The carbon dioxide reduction targets should be met on-site. Where it is clearly demonstrated that the specific targets cannot be fully achieved on-site, any shortfall may be provided off-site or through a cash in lieu contribution to the relevant borough to be ring fenced to secure delivery of carbon dioxide savings elsewhere.

Policy 5.3 Sustainable Design And Construction

Strategic

- A. *The highest standards of sustainable design and construction should be achieved in London to improve the environmental performance of the new developments and to adapt to the effects of the climate change over their lifetime.*

Policy 5.5 Decentralised energy networks

Strategic

- a. The Mayor expects 25 per cent of the heat and power used in London to be generated through the use of localised decentralised energy systems by 2025. In order to achieve this target the Mayor prioritises the development of decentralised heating and cooling networks at the development and area wide levels, including larger scale heat transmission networks.

LDF preparation

- b. Within LDFs boroughs should develop policies and proposals to identify and establish decentralised energy network opportunities. Boroughs may choose to develop this as a supplementary planning document and work jointly with neighbouring boroughs to realise wider decentralised energy network opportunities. As a minimum boroughs should:
 - a. identify and safeguard existing heating and cooling networks
 - b. identify opportunities for expanding existing networks and establishing new networks. Boroughs should use the London Heat

Policy 5.6 Decentralised energy in development proposals

Planning decisions

- A. Development proposals should evaluate the feasibility of Combined Heat and Power (CHP) systems, and where a new CHP system is appropriate also examine opportunities to extend the system beyond the site boundary to adjacent sites.
- B. Major development proposals should select energy systems in accordance with the following hierarchy:
 1. Connection to existing heating or cooling networks;
 2. Site wide CHP network;
 3. Communal heating and cooling;
- C. Potential opportunities to meet the first priority in this hierarchy are outlined in the London Heat Map tool. Where future network opportunities are identified, proposals should be designed to connect to these networks.

Policy 5.7 Renewable energy

Strategic

- A. The Mayor seeks to increase the proportion of energy generated from renewable sources, and expects that the projections for installed renewable energy capacity outlined in the Climate Change Mitigation and Energy Strategy and in supplementary planning guidance will be achieved in London.

Planning decisions

- A. Within the framework of the energy hierarchy (see Policy 5.2), major development proposals should provide a reduction in expected carbon dioxide emissions through the use of on-site renewable energy generation, where feasible.

LDF preparation

- B. Within LDFs boroughs should, and other agencies may wish to, develop more detailed policies and proposals to support the development of renewable energy in London – in particular, to identify broad areas where specific renewable energy technologies, including large scale systems and the large scale deployment of small scale systems, are appropriate. The identification of areas should be consistent with any guidelines and criteria outlined by the Mayor.
- C. All renewable energy systems should be located and designed to minimise any potential adverse impacts on biodiversity, the natural environment and historical assets, and to avoid any adverse impacts on air quality.

3.1 Energy Strategy measures checklist:

The scheme has incorporated the following measures as part of the energy strategy:

| | |
|---|---|
| Maximised potential of building orientation and massing | ✓ |
| Maximised potential of natural shading for cooling | ✓ |
| Increased building fabric performance above Building Regulations | ✓ |
| Connect to an existing energy network (where available) | |
| Created an energy network (where technically and economically viable) | |
| Communal heating | ✓ |
| Combined Heat and Power | |
| Efficient individual heating systems | |
| Ground Source Heat Pump | |
| Air Source Heat Pump | ✓ |
| Solar Thermal | |
| Photovoltaics | ✓ |
| Biomass Boiler | |

The scheme has demonstrated the following emissions reductions from each stage of the energy hierarchy for the site:

| Target | Regulated tonnes CO ₂ savings per stage | Regulated percentage CO ₂ savings per stage |
|-----------------------------------|--|--|
| | Tonnes CO ₂ /annum | % |
| Be Lean Emissions | 71.1 | 11.8% |
| Be Clean Emissions | 0 | 0% |
| Be Green Emissions | 164.7 | 27.4% |
| Cumulative on site savings | 235.8 | 39.2% |

TABLE 1 - REDUCTIONS OVER BUILDING REGULATIONS PART L 2013 FOR REGULATED EMISSIONS – SAP10

Summarising from the Greenwich Core Strategy and London Plan 2016 the development shall achieve a 42.1% CO₂ reduction over 2013 Building Regulations based on SAP10 calculations. The non-residential spaces in the development are also required to achieve BREEAM “Excellent” however it is proposed to meet a high scoring “Very Good”. Refer to section 8 for justification.

As described in policy 5.2 of the London Plan 2016 the first stage of the development would be to reduce the energy demand by improving the thermal performance of the building fabric and reducing the energy used by proposing energy efficient equipment. At the “Be Clean” stage technologies to deliver the energy in a more efficient manner will be considered. The Be Green stage will show any eventual proposal for renewable energy system for the development.

4 BASELINE EMISSIONS

In accordance with the London Plan the energy demand and carbon dioxide emissions for the residential units have been estimated in compliance with the current building regulations and in particular the requirement of Part L of the 2013 Building Regulations using Standard Assessment Procedure 2013 (SAP).

The carbon dioxide emissions for the residential units are based on initial stage SAP data (see Appendix). This section of the report will review the initial baseline load for the development as laid down in the London Renewable Toolkit and demonstrates the potential energy and CO₂ savings from the initial proposed enhancements to the scheme including the following areas:

1. Enhancements to the building fabric
2. Enhancements to low energy technologies
3. Renewable energy

Baseline is taken as compliance with the current building regulations and in particular the requirement of Part L of the 2013 Building regulations.

4.1 Part L 2013 Baseline Emissions

The following tables provide emissions data for the development extrapolated from test SAP assessments for worst case scenario flats. The flats have been chosen based on the number of exposed external wall, their orientation (i.e. top floors, corner flats and ground floor flats) and based on their typology (i.e. 1bed flat, 2 bed flat etc.), this to make sure that the initial SAP assessments is representative of the worst case scenario.

4.2 Baseline emissions

| Unit Ref | Area | TER | Unit Regulated Emissions | No. Units | Total Regulated Emissions |
|---------------------------------|----------------|-----------------------------------|-------------------------------|-----------|-------------------------------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | - | Tonnes CO ₂ /annum |
| Type 01 (1 Bed 2P) | 50 | 16.7 | 0.8 | 243 | 201.8 |
| Type 07 (3bed 5P) | 84 | 14.3 | 1.2 | 52 | 62.1 |
| Type 22 (studio) | 39 | 16.2 | 0.6 | 28 | 17.8 |
| Type 26 (2 bed 3P) | 62 | 13.7 | 0.8 | 287 | 242.1 |
| Type 25 (3 Bed 6P) | 135 | 17.0 | 2.3 | 9 | 20.7 |
| Total Baseline Emissions | | | | | 544.6 |

TABLE 2 – BASELINE EMISSIONS FOR THE RESIDENTIAL UNITS – SAP10

| Unit Ref | Area | TER | Unit Regulated Emissions | No. Units | Total Regulated Emissions |
|---------------------------------|----------------|-----------------------------------|-------------------------------|-----------|-------------------------------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | - | Tonnes CO ₂ /annum |
| Coffee shop | 104 | 66.2 | 6.9 | 1 | 6.9 |
| Flexible use | 479 | 46.2 | 22.1 | 1 | 22.1 |
| Gym | 104 | 109.7 | 11.4 | 1 | 11.4 |
| Nursery | 262 | 15.8 | 4.1 | 1 | 4.1 |
| Workshop | 1172 | 10.1 | 11.9 | 1 | 11.9 |
| Total Baseline Emissions | | | | | 56.4 |

TABLE 3 - BASELINE EMISSIONS FOR THE NON-RESIDENTIAL SPACES – SAP10

5 PROPOSED BE LEAN ENHANCEMENTS

In accordance with London Plan Policy 5.3 *Sustainable Design and Construction*, the first priority is to reduce the site baseline emissions through energy efficient design measures.

It is proposed that all domestic and non-domestic building on the development will be constructed with improvements to the building fabric, opting for a fabric first approach.

The 'Be Lean' performance values, shown in Table 4 represent the best construction practice applied to this development and represent a significant improvement over the Building Regulations Part L 2013 criteria.

| Passive measures | PART L 2013 | Proposed (TBC) |
|-------------------------------|--|---|
| U-values (W/m ² K) | - | - |
| External Walls | 0.30 | 0.17 |
| Party Walls | 0.20 | Full filled and sealed cavity (SAP U-value – 0) |
| Exposed Ground | 0.25 | 0.13 |
| Exposed Roof | 0.20 | 0.13 |
| Windows | 2.0 | 1.4 |
| Doors | 2.0 | 1.4 |
| Air-tightness | 10 m ³ /(h m ²) | 4.5m ³ /(h m ²) |
| Thermal bridging | 0.15 | 0.08 |
| Water (l/person/day) | 125 | 105 |
| Low energy lighting | 100% | 100% |

TABLE 4 - BUILDING FABRICS CHARACTERISTICS

Mechanical Ventilation

The ventilation strategy shall be system 4 mechanical supply and extract ventilation with heat recovery as described in Approved Document F. The use of MVHR will provide background and extract ventilation to kitchens / bathrooms and habitable rooms. Purge ventilation will be provided by opening windows.

Additional energy efficient measures considered at the design stage:

- Luminaire efficacy - please see SAP and BRUKL assessments for detail information

Lighting controls and HVAC efficiencies:

- Time switching
- Occupancy sensing time switch (when suitable)
- Average Heat Recovery Efficiency for MVHR: 88%
- Condensing boilers gross seasonal efficiency: 96% (benchmark boiler: ELCO R3605SB)

Heating Controls:

- Central time control
- Optimum start/stop control
- Local time control
- Local temperature control
- Weather compensation control

The Be Lean emissions for the scheme are shown in the tables below.

| Unit Ref | Area | DER | Unit Regulated Emissions | No. Units | Total Regulated Emissions |
|--|----------------|-----------------------------------|-------------------------------|-----------|-------------------------------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | - | Tonnes CO ₂ /annum |
| Type 01 (1 Bed 2P) | 50 | 14.8 | 0.7 | 243 | 178.3 |
| Type 07 (3bed 5P) | 84 | 13.2 | 1.1 | 52 | 57.4 |
| Type 22 (studio) | 39 | 15.1 | 0.6 | 28 | 16.6 |
| Type 26 (2 bed 3P) | 62 | 11.9 | 0.7 | 287 | 211.1 |
| Type 25 (3 Bed 6P) | 135 | 14.6 | 2.0 | 9 | 17.8 |
| Total Be Lean Regulated Emissions | | | | | 481.3 |

TABLE 5 - BE LEAN FOR THE RESIDENTIAL UNITS – SAP10

| | Regulated tonnes CO ₂ savings per stage | Regulated percentage CO ₂ savings per stage |
|-----------------------------------|--|--|
| | Tonnes CO ₂ /annum | % |
| Be Lean Emissions | 63.2 | 11.6% |
| Be Clean Emissions | | |
| Be Green Emissions | | |
| Cumulative on site savings | 63.2 | 11.6% |

TABLE 6 - CARBON EMISSIONS ASSOCIATED TO FABRIC IMPROVEMENTS FOR THE RESIDENTIAL UNITS –SAP10




FIGURE 1 – BE LEAN CARBON REDUCTION EMISSIONS FOR RESIDENTIAL UNITS –SAP10

| Unit Ref | Area | DER | Unit Emissions | Regulated | No. Units | Total | Regulated |
|--|----------------|-----------------------------------|-------------------------------|-----------|-----------|-------------------------------|-----------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | | - | Tonnes CO ₂ /annum | |
| Coffee shop | 104 | 60.3 | 6.3 | | 1 | 6.3 | |
| Flexible use | 479 | 38.8 | 18.6 | | 1 | 18.6 | |
| Gym | 104 | 107.1 | 11.1 | | 1 | 11.1 | |
| Nursery | 262 | 13.9 | 3.6 | | 1 | 3.6 | |
| Workshop | 1172 | 7.6 | 9 | | 1 | 9 | |
| Total Be Lean Regulated Emissions | | | | | | 48.5 | |

TABLE 7 - BE LEAN CARBON EMISSIONS FOR NON-RESIDENTIAL SPACES –SAP10

| Target | Regulated savings per stage | tonnes CO ₂ | Regulated percentage savings per stage |
|-----------------------------------|-------------------------------|------------------------|--|
| | Tonnes CO ₂ /annum | | % |
| Be Lean Emissions | 8 | | 14.0% |
| Be Clean Emissions | | | |
| Be Green Emissions | | | |
| Cumulative on site savings | 8 | | 14.0% |

TABLE 8 - CARBON EMISSIONS REDUCTIONS ASSOCIATED TO FABRIC IMPROVEMENTS FOR NON-RESIDENTIAL SPACES – SAP10




FIGURE 2 - BE LEAN CARBON REDUCTION EMISSIONS FOR NON-RESIDENTIAL SPACES –SAP10

| Building use | Energy demand following energy efficiency measures (MWh/year) | | | | |
|--------------|---|-----------|----------|-----------|---------|
| | Space Heating | Hot Water | Lighting | Auxiliary | Cooling |
| Domestic | 575.5 | 1238.3 | 165.6 | 103.8 | 0.0 |
| Non-domestic | 28.1 | 127.8 | 39.7 | 10.1 | 19.5 |

TABLE 9- ENERGY DEMAND FOLLOWING ENERGY EFFICIENCY MEASURES – SAP10

| | Cooling Energy | | | | |
|--------------|----------------|------------|------------------|------------|--------------------|
| | Actual | | | Notional | |
| | m2 | kWh/m2year | MJ/year | kWh/m2year | MJ/year |
| Coffee shop | 103.7 | 6.53 | 2437.7796 | 13.85 | 5170.482 |
| Nursery | 261.5 | 20.89 | 19665.846 | 31.28 | 29446.992 |
| Flexible use | 478.5 | 9.12 | 15710.112 | 16.65 | 28681.29 |
| Workshop | 1172.7 | 7.17 | 30269.7324 | 8.1 | 34195.932 |
| Gym | 103.6 | 5.9 | 2200.464 | 7.63 | 2845.6848 |
| Total | | | 70283.934 | | 100340.3808 |

TABLE 10 – COOLING DEMAND FOR THE DEVELOPMENT

| | Target Fabric Energy Efficiency (kWh/m ²) | Dwelling Fabric Energy Efficiency (kWh/m ²) | Improvement (%) |
|-------------------|---|---|-----------------|
| Development total | 36.27 | 34.13 | 5.91% |

TABLE 11- FABRIC EFFICIENCY IMPROVEMENT RESIDENTIAL UNITS– SAP10

6 PROPOSED BE CLEAN ENHANCEMENTS

In accordance with GLA Guidance, proposals should select energy systems in accordance with the following hierarchy:

1. Connection to existing heating or cooling networks;
2. Zero-emission or local secondary heat sources (in conjunction with heat pump);
3. Low –emissions CHP (only for area-wide heat network);
4. Ultra-low NOx gas boilers.

6.1 Connection to existing heating or cooling networks

In line with the requirements of the London Plan, the report has considered the feasibility of connecting into an existing or planned local district heating network.





FIGURE 3 – LONDON HEAT MAP SCREENSHOT

The London heat map shows that the site is located within an area of heat decentralised energy potential in accordance with the Heat Map toolkit and planned district heating networks are in the vicinity of the development. RGB have confirmed that the only large scale communal heat system is located in the neighbouring development from Berkeley, with whom an investigation was undertaken to establish whether it was possible for Kidbrooke Square Station to connect to their Energy Centre. An initial response has now been received where Berkeley have stated their concerns regarding the feasibility of the connection.

In addition Berkeley have responded regarding the capacity of their systems and have said that: “the Energy Centre in Phase 3 has capacity for our (Berkeley Homes’) current proposals for Kidbrooke Village. Significant additional work would be required to understand if additional capacity could be added to the network. “The Berkeley Homes Energy Centre has not been designed to accommodate the demand from adjacent sites outside of the Kidbrooke Village Masterplan.

At this stage we have based our proposal on a site energy centre containing Air Source Heat Pumps, in addition infrastructure will be installed from the energy centre to the site boundary to facilitate future connection if feasible.



Hi Dimitrios

The area of Kidbrooke Station development is the area of decentralised energy potential. Large scale communal systems will be present in the Berkley homes development in the vicinity. There are no other planned DNH I am aware of.

Best regards,

Lawrence

Thanks for your email. Tamsin raised this with me yesterday and she is looking into the detail. This may take a little time but she will come back to Sam. In the meantime, please see below a brief summary.

There is no Esco in place for KV at present, however this is our intention in the long term. The DH Network does not extend north of the railway line it crosses Kidbrooke Park Road, east-west between Phase 3 and Phase 2/6 only.

The railway line, the railway bridge and the third party land ownership (Network Rail?) are a physical impediment to any DH Network connection, which in my view, might make the likelihood of sharing any capacity extremely complicated and costly to undertake.

Tamsin will come back to you with the detail we can ascertain asap.

Kind regards

Hi Sam

I hope you are well and apologise for the delayed response.

In response to your question regarding capacity, the Energy Centre in Phase 3 has capacity for our current proposals for Kidbrooke Village. Significant additional work would be required to understand if additional capacity could be added to the network.

I think David has addressed the remaining queries in his previous email, but any further queries, please just let me know.

Many thanks

6.2 Site-wide Network

GLA has advised to explore the utilisation of Air Source Heat Pumps in favour of a site wide CHP network as per the draft London Plan Policy S13 Energy Infrastructure and GLA Energy Assessment Guidance (Oct 18). Therefore improvements from ASHPs are demonstrated in the “Be Clean” section of this report

| Unit Ref | Area | DER | Unit Regulated Emissions | No. Units | Total Regulated Emissions |
|--|----------------|-----------------------------------|-------------------------------|-----------|-------------------------------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | - | Tonnes CO ₂ /annum |
| Type 01 (1 Bed 2P) | 50 | 14.8 | 0.7 | 243 | 178.3 |
| Type 07 (3bed 5P) | 84 | 13.2 | 1.1 | 52 | 57.4 |
| Type 22 (studio) | 39 | 15.1 | 0.6 | 28 | 16.6 |
| Type 26 (2 bed 3P) | 62 | 11.9 | 0.7 | 287 | 211.1 |
| Type 25 (3 Bed 6P) | 135 | 14.6 | 2.0 | 9 | 17.8 |
| Total Be Lean Regulated Emissions | | | | | 481.3 |

TABLE 12 - BE CLEAN REDUCTIONS OVER 2013 BUILDING REGULATION BASELINE FOR THE RESIDENTIAL UNITS – SAP10

| | Regulated tonnes CO ₂ savings per stage | Regulated percentage CO ₂ savings per stage |
|-----------------------------------|--|--|
| | Tonnes CO ₂ /annum | % |
| Be Lean Emissions | 63.2 | 11.6% |
| Be Clean Emissions | 0 | 0% |
| Be Green Emissions | | |
| Cumulative on site savings | 63.2 | 11.6% |

TABLE 13 - BE CLEAN REDUCTIONS OVER 2013 BUILDING REGULATION BASELINE FOR RESIDENTIAL UNITS– SAP10




FIGURE 4 - BE CLEAN CARBON REDUCTION EMISSIONS FOR RESIDENTIAL UNITS – SAP10

| Unit Ref | Area | DER | Unit Emissions | Regulated | No. Units | Total Regulated Emissions |
|--|----------------|-----------------------------------|-------------------------------|-----------|-------------------------------|---------------------------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | - | Tonnes CO ₂ /annum | |
| Coffee shop | 104 | 60.3 | 6.3 | 1 | 6.3 | |
| Flexible use | 479 | 38.8 | 18.6 | 1 | 18.6 | |
| Gym | 104 | 107.1 | 11.1 | 1 | 11.1 | |
| Nursery | 262 | 13.9 | 3.6 | 1 | 3.6 | |
| Workshop | 1172 | 7.6 | 9 | 1 | 9 | |
| Total Be Lean Regulated Emissions | | | | | 48.5 | |

TABLE 14 - BE CLEAN REDUCTIONS OVER 2013 BUILDING REGULATION BASELINE FOR THE NON-RESIDENTIAL SPACES – SAP10

| Target | Regulated tonnes CO ₂ savings per stage | Regulated percentage CO ₂ savings per stage |
|-----------------------------------|--|--|
| | Tonnes CO ₂ /annum | % |
| Be Lean Emissions | 8 | 14.0% |
| Be Clean Emissions | 0 | 0% |
| Be Green Emissions | | |
| Cumulative on site savings | 8 | 14.0% |

TABLE 15 - BE CLEAN REDUCTIONS OVER 2013 BUILDING REGULATION BASELINE FOR NON-RESIDENTIAL UNITS SPACES – SAP10




FIGURE 5 – BE CLEAN CARBON REDUCTION EMISSIONS FOR NON-RESIDENTIAL SPACES–SAP10

7 PROPOSED 'BE GREEN' ENHANCEMENTS

The following section examines the potential feasibility of also incorporating renewable technologies to provide a further carbon dioxide reduction through onsite renewable.

The following technologies have been reviewed:

- Wind Turbines
- Photovoltaic
- Solar Thermal
- Heat Pumps
- Biomass Heating

Wind Turbines

Wind turbines can have outputs ranging from a few watts to several megawatts and produce electricity without emitting CO₂. Energy is extracted from the wind using a rotor generally consisting of two or three blades, which have a profile similar to that of an airplane wing. If the diameter of the rotor is doubled, the power output from the turbine is quadrupled at a given wind speed.

Correct assessment of the resource and sighting is critical before considering the installation of a turbine. Potential sites generally need average wind speeds of greater than 5m/s at hub height to be economically viable in the UK, although small roof mounted wind turbines (typically 1.5kW) can work at wind speeds as low as 3.5m/s. Wind energy availability varies on a seasonal basis and peaks during the winter months, which matches well with the seasonal variation in energy requirements in a development.

Although best suited to rural environments, modern wind turbines are becoming increasingly cost effective in low-density areas where there is often the opportunity to connect them immediately to the grid, or use the electricity generated directly in a dwelling. For higher density housing, they are not as cost-effective as their output will be affected by lower and disrupted average wind speeds. Rooftop mounted turbines are becoming increasingly available, where the higher average wind speeds at increased hub heights contribute to improved performance.






SUMMARY:

A stand-alone wind turbine can be excluded from consideration, as it would require sufficient open space available on the site to locate the turbine and to be far enough away from building to be able to work effectively with minimum turbulence. There appears to be no open space of sufficient size around the development to allow for this and so has been removed from consideration.

Also building mounted wind turbines may be limited due to the environmental conditions of the site, in that it may be difficult to achieve the requisite wind speeds in order make this technology a feasible option. There may also be potential issues with regard to visual amenity and noise generation associated with certain types of wind turbine. Wind turbines have therefore been excluded from further consideration for the development.

| | |
|---|--|
| <p>Photovoltaic</p> | |
| <p>Photovoltaic or 'PV' systems convert energy from the sun into electricity through semi-conductor cells. A cell consists of a junction between two thin layers of dissimilar semi-conducting materials, based on silicon. When light shines on the junction, a difference in energy is created – otherwise known as 'voltage' or 'potential difference'. This voltage is used to produce an electrical current or direct current (DC), which can be used directly or converted into alternating current (AC). The brighter the sunlight, the more power is produced – although PV cells still produce a reduced level of power when the sun is hidden by clouds. Shading from other objects (such as nearby buildings and trees) is a key issue, as PV cells are more likely to show a drop in system output than solar thermal panels. Ideally panels should face as close to due south as possible, and not be shaded. Individual PV cells only produce a small amount of power, so are connected together to form a module. Modules can then be linked to form an array and sized to meet a particular load.</p> <p>There are three main types of solar cells readily available in the UK:</p> <p><i>Monocrystalline</i> – very thin wafers of silicon cut from a small seed crystal. More efficient than polycrystalline, but more expensive due to the manufacturing process.</p> <p><i>Polycrystalline</i> – instead of one crystal, several different crystals are used for producing the slices. The result is cheaper PV cells than monocrystalline but lower efficiencies.</p> <p><i>Amorphous silicon</i> – silicon is made into a continuous strip of film. Cells can be produced more quickly and hence cheaply than mono or polycrystalline, but with substantially lower efficiencies.</p> |  |
| <p>SUMMARY:</p> <p>A photovoltaic system has been included to provide further carbon reduction. The PV panels will be installed on the building flat roof. Vertical photovoltaic panels are not viable on the proposed development not only due to their decreased efficiency and significant higher maintenance cost, but also due to the nature of the development which is mostly residential and thus the fenestrations inhibit the installation.</p> | |

| | |
|--|---|
| <p>Solar Thermal</p> <p>Solar thermal or solar hot water (SHW) systems for use in dwellings use a heat collector, which is generally mounted on a roof and contains a fluid (typically water with glycol) that is heated by the sun. The heated liquid is then passed through a coil in a hot water storage vessel. The heated water in the vessel may then be supplied directly, or raised to a higher temperature (if required) by a supplementary heater. In this way the ‘free’ energy obtained from the sun can be used to offset the amount of energy that would be required to heat the water, and will reduce both running costs (due to the fuel being displaced) and the associated CO₂ emissions. These systems do not generally provide space heating, and are among the most cost-effective renewable energy systems that can be installed on dwellings in rural or urban environments.</p> <p>It must be remembered that solar thermal load must be matched to the hot water load and storage vessel sized appropriately to maximise the solar thermal energy.</p> |   |
| <p>SUMMARY:</p> <p>Solar thermal systems have not been considered suitable as will be in conflict with the ASHPs for the summer time thermal load of the development.</p> | |

| Heat Pumps – Ground Source | |
|--|---|
| <p>Ground Source - In the UK the earth, a few meters below the surface, keeps a constant temperature of about 11-12°C throughout the year. This temperature is maintained due to the ground's high thermal mass, which stores heat from the sun during the summer. Ground Source Heat Pumps (GSHP) can transfer this heat from the ground by a vapour compression cycle into a building to provide space heating and, in some cases, pre-heating for domestic hot water. For every unit of electricity used to operate the heat pump, 3-4 units of heat are produced, this is known as a heat pumps Coefficient of Performance (COP).</p> <p>There are three important elements to a GSHP:</p> <p><i>Ground loop</i> - comprises lengths of pipe buried in the ground, either in a borehole or a horizontal trench. The pipe is a closed circuit and is filled with a mixture of water and antifreeze, which is pumped round the pipe absorbing heat from the ground. (Pictured)</p> <p><i>Heat pump</i> – Exchanges the heat in the buried pipe work through a heat exchanger to a secondary water circuit.</p> <p><i>Heat distribution system</i> - under floor heating or oversized radiators for space heating and in some cases water storage for hot water supply.</p> |  |
| <p>SUMMARY:</p> <p>Ground Source Heat Pumps systems would be in conflict with the ASHPs for the summer time thermal load of the development therefore have not been considered suitable for this site.</p> | |

Heat Pumps – Air Source

Air Source Heat Pumps extract heat energy from a source and transfers that heat into a building by means of either, under-floor heating system (most efficient), radiators (oversized to counter the low flow temperatures). An electric heat pump can potentially deliver 4kW of heat energy for every 1kW of electrical energy used to power the pump (CoP 4:1). This technology could provide the majority of the heating for an individual dwelling or development for the year. Back up heating is provided by either a standard boiler or electric heating unit integral within the system.

ASHP's require either an area to mount an external condenser or ducting for internal exhaust air systems.

There are two main types of Air Source Heat Pumps,

Air-to-Water- comprises of an external heat pump unit and an internal unit containing the cylinder, expansion vessel and electric heater. The heat pump extracts heat energy from the outside atmospheric air. The heat pump removes the heat in the air and transfers that heat energy via a refrigerant, where the temperature is raised to heat domestic hot water and heating water systems. Back up heating is provided by an electric heating unit integral within the systems.

Exhaust Air Heat Pumps – Mechanical ventilation system combined with a heat pump, which extracts air via ductwork connected to the warm areas of the dwelling such as bathrooms, kitchens and utility rooms. Heat is removed from the air and transferred into the heat pump where the temperature is raised to heat the domestic hot water and radiator water. Back up heating is provided by an electric heating unit integral within the system.

Summary:

Air Source Heat Pumps systems have been selected to provide a percentage of the heat load of the development as it will be demonstrated in this report

| Biomass Boiler | |
|---|--|
| <p>Biomass is a term used to define all plant and animal material and has been used as an energy source for centuries. Although there are a number of different technologies available that extract heat from biomass, wood burning systems are most likely to be appropriate for use in community systems. Biomass or wood burning systems differ from other renewable energy sources in that CO₂ is emitted when it is burned to produce heat. However the amount of CO₂ released is only the same as the amount of carbon absorbed by the tree whilst it was growing and therefore considered essentially a carbon neutral approach.</p> <p>Wood fuel can be sourced in three main forms, logs, pellets and woodchip. Logs are one of the simplest, quickest and cheapest forms of using wood fuel, although their energy density is half that of pellets, and a quarter of the energy density in woodchip.</p> <p>When the technology is used on a large development for burning wood fuel it involves the use of large automatic wood chip/pellet boilers situated in a main heating centre with adjacent wood pellet fuel stores to supply the boiler. Due to the slow response rates of the boilers a thermal store can be included in the installation to smooth out the demand requirements and allows the boilers to charge the store and then set back to stand-by mode as the energy store is used.</p> <p>The following must be considered at the early stages of a project to ensure a successful biomass scheme:</p> <ol style="list-style-type: none"> 1. Fuel sourcing 2. Delivery of the fuel to the fuel store 3. Fuel handling 4. Boiler sizing and control 5. Local Environmental Pollution | |
| <p>SUMMARY:</p> <p>A biomass system is not considered viable due to limited room available (require a large fuel storage), high maintenance requirements, embodied carbon of fuel deliveries and effects to local air quality. For these reasons is not a suitable renewable technology for this development.</p> | |



7.1 General

To complete the energy hierarchy renewable energy systems have been considered and Air Source Heat Pumps have been selected. The ASHPs along with the use of Photovoltaic panels are able to achieve and surpass 35% savings of CO₂ emissions against Building Regulations 2013.

7.2 Air Source Heat Pumps

It is proposed to install ASHPs to minimise the carbon emissions for the development. The ASHPs are to cover the 60% of the heat demand of the annual load of the development with an annual efficiency of 285%. In the evaluation of the annual efficiency on the ASHP the London_LHR_DSY1_2020High90 weather file has been utilised. As the manufacturers provide the efficiency of the unit in temperature ranges, the worst case scenario was considered in the estimation of the efficiency and output of the ASHP (e.g. for the temperature range 7 °C >= and <10 °C it has been assumed that efficiency and output of the ASHP will be that of 7°C). For the calculations for the proposed development the 4 No Mitsubishi CAHV-P500YA models has been considered to be serving the development, however any air source heat pump arrangement can be utilised providing the cover the 60% of the heat demand of the annual load of the development with an annual efficiency of 285%.

| Capacity kW | | External/ Intake Temperature °C | | | | | | | | | | | | | | | |
|-----------------------------|----|---------------------------------|------|------|------|------|------|------|------|----|----|----|----|----|----|----|----|
| | | -20 | -15 | -10 | -7 | -5 | 0 | 2 | 5 | 7 | 10 | 16 | 20 | 25 | 30 | 35 | 40 |
| Outlet Water temperature °C | 35 | 0 | 0 | 40.3 | 42.2 | 42.4 | 42.7 | 42.8 | 43.5 | 45 | 45 | 45 | 45 | 45 | 45 | 45 | 45 |
| | 45 | 32 | 37.4 | 40.6 | 42.4 | 42.6 | 42.9 | 43 | 43.5 | 45 | 45 | 45 | 45 | 45 | 45 | 45 | 45 |
| | 55 | 32.2 | 37.7 | 40.8 | 42.7 | 42.8 | 43.1 | 43.2 | 43.6 | 45 | 45 | 45 | 45 | 45 | 45 | 45 | 45 |
| | 60 | 32.2 | 37.8 | 40.9 | 42.8 | 42.9 | 43.2 | 43.3 | 43.7 | 45 | 45 | 45 | 45 | 45 | 45 | 45 | 45 |
| | 65 | 32.2 | 37.9 | 41 | 42.9 | 43 | 43.3 | 43.4 | 43.7 | 45 | 45 | 45 | 45 | 45 | 45 | 45 | 45 |
| | 70 | 0 | 0 | 41.1 | 43 | 43.1 | 43.4 | 43.5 | 43.7 | 45 | 45 | 45 | 45 | 45 | 45 | 45 | 45 |

TABLE 16 – MITSUBISHI CAHV-P500YA OUTPUT CAPACITY PER UNIT

| Input kW | | External/ Intake Temperature °C | | | | | | | | | | | | | | | |
|-----------------------------|----|---------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | -20 | -15 | -10 | -7 | -5 | 0 | 2 | 5 | 7 | 10 | 16 | 20 | 25 | 30 | 35 | 40 |
| Outlet Water temperature °C | 35 | 0 | 0 | 17 | 16.9 | 16.2 | 14.7 | 14.2 | 12 | 10.9 | 9.82 | 8.2 | 7.4 | 6.6 | 6.3 | 6.02 | 5.77 |
| | 45 | 18.4 | 19.4 | 19.4 | 19.5 | 18.7 | 17 | 16.4 | 14.2 | 12.9 | 11.9 | 10.1 | 9.08 | 8.05 | 7.73 | 7.44 | 7.17 |
| | 55 | 21.2 | 22.5 | 22.7 | 22.8 | 22 | 20.1 | 19.5 | 17.5 | 16.5 | 15.2 | 13.2 | 12.1 | 11 | 10.3 | 9.75 | 9.24 |
| | 60 | 22.9 | 24.5 | 24.8 | 25 | 24.1 | 22.1 | 21.4 | 19.1 | 17.8 | 16.6 | 14.7 | 13.6 | 12.4 | 11.6 | 10.8 | 10.2 |
| | 65 | 24.9 | 26.8 | 27.3 | 27.6 | 26 | 24.6 | 23.9 | 22.2 | 21.3 | 19.6 | 16.9 | 15.4 | 14 | 13 | 12.1 | 11.4 |
| | 70 | 0 | 0 | 30.2 | 30.8 | 29.8 | 27.6 | 26.9 | 25.7 | 25.6 | 23.9 | 19.9 | 18 | 16 | 14.8 | 13.8 | 12.9 |

TABLE 17 – MITSUBISHI CAHV-P500YA ELECTRICAL INPUT PER UNIT

| COP | | External/ Intake Temperature °C | | | | | | | | | | | | | | | |
|-----------------------------|----|---------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | -20 | -15 | -10 | -7 | -5 | 0 | 2 | 5 | 7 | 10 | 16 | 20 | 25 | 30 | 35 | 40 |
| Outlet Water temperature °C | 35 | 0.00 | 0.00 | 0.00 | 2.37 | 2.50 | 2.62 | 2.90 | 3.01 | 3.63 | 4.13 | 4.58 | 5.49 | 6.08 | 6.82 | 7.14 | 7.48 |
| | 45 | 1.74 | 1.74 | 1.93 | 2.09 | 2.17 | 2.28 | 2.52 | 2.62 | 3.06 | 3.49 | 3.78 | 4.46 | 4.96 | 5.59 | 5.82 | 6.05 |
| | 55 | 1.52 | 1.52 | 1.68 | 1.80 | 1.87 | 1.95 | 2.14 | 2.22 | 2.49 | 2.73 | 2.96 | 3.41 | 3.72 | 4.09 | 4.37 | 4.62 |
| | 60 | 1.41 | 1.41 | 1.54 | 1.65 | 1.71 | 1.78 | 1.95 | 2.02 | 2.29 | 2.53 | 2.71 | 3.06 | 3.31 | 3.63 | 3.88 | 4.17 |
| | 65 | 1.29 | 1.29 | 1.41 | 1.50 | 1.55 | 1.65 | 1.76 | 1.82 | 1.97 | 2.11 | 2.30 | 2.66 | 2.92 | 3.21 | 3.46 | 3.72 |
| | 70 | 0.00 | 0.00 | 0.00 | 1.36 | 1.40 | 1.45 | 1.57 | 1.62 | 1.70 | 1.76 | 1.88 | 2.26 | 2.50 | 2.81 | 3.04 | 3.26 |

TABLE 18 – MITSUBISHI CAHV-COP (COP CALCULATED AS DESCRIBED ABOVE)

| Heat Requirement | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|------------------------------|--------|--------|--------|--------|--------|-------|-------|--------|--------|--------|--------|--------|
| Residential HWS Demand (MWh) | 160.14 | 104.64 | 59.64 | 14.74 | 2.64 | 0.00 | 0.00 | 0.00 | 0.00 | 23.88 | 92.84 | 166.34 |
| Residential HTG Demand (MWh) | 130.78 | 115.49 | 121.83 | 109.95 | 108.29 | 97.54 | 94.41 | 102.58 | 102.08 | 113.98 | 119.59 | 127.88 |
| Commercial HTG Demand (MWh) | 3.75 | 2.45 | 1.39 | 0.34 | 0.06 | 0.00 | 0.00 | 0.00 | 0.00 | 0.56 | 2.17 | 3.89 |
| Commercial HWS Demand (MWh) | 0.10 | 0.09 | 0.10 | 0.09 | 0.09 | 0.08 | 0.07 | 0.08 | 0.08 | 0.09 | 0.09 | 0.10 |
| Total | 294.77 | 222.67 | 182.96 | 125.12 | 111.08 | 97.61 | 94.48 | 102.66 | 102.16 | 138.51 | 214.70 | 298.22 |

TABLE 19 – HEAT REQUIREMENTS

In order to maximise the utilisation of the ASHPs it has to be considered that any difference between the outlet temperature of the ASHP and the temperature of the flow of the communal heating system constricts the utilisation of the ASHP, for example if the communal heating system is designed to run at 70°C-40°C and the outlet of the ASHP is at 55°C, the ASHP would only be able to cover up to 50% of the load as it would only be able to raise the temperature to 55°C and the rest 15°C raise in temperature had to be covered from the boilers. Therefore the system flow temperature should be minimised to enable the ASHP to cover the maximum allowable percentage of the total heating requirements.

As the HIUs have to be able to achieve 55°C at the hot water outlets in the flats it is proposed that the heating system flow temperature is to be set at 65°C

At the same time it has to be considered that the ASHP have to run efficiently (at an average of 285% efficiency in this case) and as well as cover a significant proportion of the total heat demand (60% in this case).

Additional factors that need to be considered is that the ASHP have to be utilised at the maximum practically degree to minimise the installation, maintenance and infrastructure costs and that the ASHP should be able to be used without the use of boilers as the later would minimise the CO₂ emissions during warm periods. The importance of the latter is increased the predictions for rising average temperatures.

Therefore it is proposed that the ASHP would have a varying outlet temperature based on the temperature of the air intake (which shall be determined by a temperature sensor located next to the ASHPs). With this method the controls of the system are simplified and the ASHP utilisation and efficiency is maximised and in addition any adaptation to changing weather conditions is straight forward. For the development the proposed outlet temperatures are as per Table 20. When the ASHP output is at 65°C the ASHP would be supplying the development (or filling the buffer vessels) directly and when it is set lower they will be used in conjunction with the boilers. During the hours at which the ASHP is set to deliver water less than 55°C their output is restricted to accordingly (66.67% and 33.33% in this case) of the heating requirement extrapolated for that duration.

| | | | | | | | | | | | | | | | | |
|---------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|-----|-----|
| External Temp °C | 40 | 35 | 30 | 25 | 20 | 16 | 10 | 7 | 5 | 2 | 0 | -5 | -7 | -10 | -15 | -20 |
| ASHP Outlet Temp °C | 65 | 65 | 65 | 65 | 65 | 55 | 55 | 45 | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 |

TABLE 20 – ASHP OUTLET TEMPERATURE VS INTAKE AIR TEMPERATURE

| Month | Heat Demand kWh | System Flow Temp °C | System Return Temp °C | Heat Demand Covered By ASHP kWh | Heat Demand Covered By ASHP | Average COP | Hours of ASHP operation |
|--------------|-----------------|---------------------|-----------------------|---------------------------------|-----------------------------|-------------|-------------------------|
| Jan | 293234 | 65 | 35 | 116280.0 | 39.7% | 2.89 | 646.0 |
| Feb | 221882 | 65 | 35 | 101700.0 | 45.8% | 2.91 | 565.0 |
| Mar | 182910 | 65 | 35 | 121940.3 | 66.7% | 2.88 | 677.4 |
| Apr | 125684 | 65 | 35 | 84020.6 | 66.9% | 2.89 | 466.8 |
| May | 111820 | 65 | 35 | 101383.8 | 90.7% | 2.85 | 563.2 |
| Jun | 98314 | 65 | 35 | 93287.1 | 94.9% | 2.88 | 518.3 |
| Jul | 95162 | 65 | 35 | 95161.8 | 100.0% | 3.05 | 528.7 |
| Aug | 103400 | 65 | 35 | 103399.7 | 100.0% | 2.91 | 574.4 |
| Sep | 102895 | 65 | 35 | 102895.1 | 100.0% | 2.81 | 571.6 |
| Oct | 138962 | 65 | 35 | 115410.6 | 83.1% | 2.82 | 641.2 |
| Nov | 214121 | 65 | 35 | 112680.0 | 52.6% | 2.88 | 626.0 |
| Dec | 296567 | 65 | 35 | 123840.0 | 41.8% | 2.89 | 688.0 |
| Total | 1984951 | | | 1271999.0 | 64.1% | 2.89 | 7066.7 |

TABLE 21 – SUMMARY OF ASHP OPERATION

To ensure that the Air Source Heat Pumps are operating for the maximum timeframe per day; buffer vessels will be utilised.

| External Temperature | 40°C | | | 35°C | | | 30°C | | | 25°C | | |
|----------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|
| | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh |
| Jan | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 0 | 65 | 2.92 | 0 |
| Feb | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 0 | 65 | 2.92 | 0 |
| Mar | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 0 | 65 | 2.92 | 1440 |
| Apr | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 0 | 65 | 2.92 | 0 |
| May | 65 | 3.72 | 0 | 65 | 3.46 | 360 | 65 | 3.21 | 8280 | 65 | 2.92 | 28080 |
| Jun | 65 | 3.72 | 0 | 65 | 3.46 | 1440 | 65 | 3.21 | 18900 | 65 | 2.92 | 26100 |
| Jul | 65 | 3.72 | 720 | 65 | 3.46 | 9180 | 65 | 3.21 | 29160 | 65 | 2.92 | 47700 |
| Aug | 65 | 3.72 | 0 | 65 | 3.46 | 180 | 65 | 3.21 | 20340 | 65 | 2.92 | 53460 |
| Sep | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 5580 | 65 | 2.92 | 45720 |
| Oct | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 0 | 65 | 2.92 | 5760 |
| Nov | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 0 | 65 | 2.92 | 0 |
| Dec | 65 | 3.72 | 0 | 65 | 3.46 | 0 | 65 | 3.21 | 0 | 65 | 2.92 | 0 |

TABLE 22 – DETAIL OPERATION OF ASHP 1 OF 4

| External Temperature | 20°C | | | 16°C | | | 10°C | | | 7°C | | |
|----------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|
| Month | ASHP Outlet Temp °C | ASHP COP | Actual Output kWh | ASHP Outlet Temp °C | ASHP COP | Actual Output kWh | ASHP Outlet Temp °C | ASHP COP | Actual Output kWh | ASHP Outlet Temp °C | ASHP COP | Actual Output kWh |
| Jan | 65 | 2.66 | 0 | 55 | 2.96 | 54360 | 55 | 2.73 | 44460 | 45 | 3.06 | 17460 |
| Feb | 65 | 2.66 | 900 | 55 | 2.96 | 48420 | 55 | 2.73 | 31320 | 45 | 3.06 | 21060 |
| Mar | 65 | 2.66 | 8820 | 55 | 2.96 | 71820 | 55 | 2.73 | 32040 | 45 | 3.06 | 7820 |
| Apr | 65 | 2.66 | 540 | 55 | 2.96 | 57960 | 55 | 2.73 | 25521 | 45 | 3.06 | 0 |
| May | 65 | 2.66 | 37080 | 55 | 2.96 | 22704 | 55 | 2.73 | 4340 | 45 | 3.06 | 540 |
| Jun | 65 | 2.66 | 37440 | 55 | 2.96 | 3827 | 55 | 2.73 | 5040 | 45 | 3.06 | 540 |
| Jul | 65 | 2.66 | 8402 | 55 | 2.96 | 0 | 55 | 2.73 | 0 | 45 | 3.06 | 0 |
| Aug | 65 | 2.66 | 29420 | 55 | 2.96 | 0 | 55 | 2.73 | 0 | 45 | 3.06 | 0 |
| Sep | 65 | 2.66 | 51595 | 55 | 2.96 | 0 | 55 | 2.73 | 0 | 45 | 3.06 | 0 |
| Oct | 65 | 2.66 | 52560 | 55 | 2.96 | 55282 | 55 | 2.73 | 1809 | 45 | 3.06 | 0 |
| Nov | 65 | 2.66 | 4680 | 55 | 2.96 | 59580 | 55 | 2.73 | 36540 | 45 | 3.06 | 11880 |
| Dec | 65 | 2.66 | 1260 | 55 | 2.96 | 47340 | 55 | 2.73 | 48960 | 45 | 3.06 | 26280 |

TABLE 23 – DETAIL OPERATION OF ASHP 2 OF 4

| External Temperature | 5°C | | | 2°C | | | 0°C | | | -5°C | | |
|----------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|
| Month | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh |
| Jan | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Feb | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Mar | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Apr | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| May | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Jun | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Jul | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Aug | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Sep | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Oct | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Nov | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |
| Dec | 35 | 3.01 | 0 | 35 | 2.90 | 0 | 35 | 2.62 | 0 | 35 | 2.50 | 0 |

TABLE 24 – DETAIL OPERATION OF ASHP 3 OF 4

| External Temperature | -7°C | | | -10°C | | | -15°C | | | -20°C | | |
|----------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|---------------------|----------|-------------------|
| Month | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh | ASHP Outlet Temp oC | ASHP COP | Actual Output kWh |
| Jan | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Feb | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Mar | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Apr | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| May | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Jun | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Jul | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Aug | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Sep | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Oct | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Nov | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |
| Dec | 35 | 2.37 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 | 35 | 0.00 | 0.0 |

TABLE 25 – DETAIL OPERATION OF ASHP 4 OF 4

|

Table 26 & Table 27 below are illustrating the estimated, as per the government approved SAP software NHER Plan Assessor v 6.2.3, the yearly fuels costs per flat type for the heating and hot water for the baseline flat types and the design flat types. Please also note that this does not take into consideration occupants varying usage of heating and hot water nor the percentage of occupancy of the development which affects pumping cost.

| | Type 01 (1 Bed 2P) | Type 07 (3bed 5P) | Type 22 (studio) | Type 26 (2 bed 3P) | Type 25 (3 Bed 6P) |
|---------------------------------|--------------------|-------------------|------------------|--------------------|--------------------|
| Boilers HTG | £61.26 | £106.54 | £33.23 | £55.37 | £293.76 |
| ASHP HTG | £0.00 | £0.00 | £0.00 | £0.00 | £0.00 |
| BOILERS HWS | £77.63 | £91.73 | £72.75 | £83.45 | £98.08 |
| ASHP HWS | £0.00 | £0.00 | £0.00 | £0.00 | £0.00 |
| Pumps/ Fans | £0.00 | £0.00 | £0.00 | £0.00 | £0.00 |
| Electricity for Lighting | £30.63 | £48.31 | £25.14 | £38.36 | £63.15 |
| Service Charges | £25.00 | £25.00 | £25.00 | £25.00 | £25.00 |
| Metering & Billing | £80.00 | £80.00 | £80.00 | £80.00 | £80.00 |
| Plant Maintenance | £110.00 | £110.00 | £110.00 | £110.00 | £110.00 |
| ASHP Maintenance | £20.00 | £20.00 | £20.00 | £20.00 | £20.00 |
| Total | £404.52 | £481.58 | £366.12 | £412.18 | £689.99 |

TABLE 26 – BASELINE YEARLY FUEL COSTS (ONLY) PER FLAT TYPE AS PER SAPs - BOILERS

| | Type 01 (1 Bed 2P) | Type 07 (3bed 5P) | Type 22 (studio) | Type 26 (2 bed 3P) | Type 25 (3 Bed 6P) |
|--------------------------|--------------------|-------------------|------------------|--------------------|--------------------|
| Boilers HTG | £16.48 | £35.85 | £8.94 | £12.59 | £96.00 |
| ASHP HTG | £24.72 | £53.77 | £13.41 | £18.89 | £144.00 |
| BOILERS HWS | £35.12 | £41.24 | £33.00 | £37.64 | £44.00 |
| ASHP HWS | £52.67 | £61.86 | £49.49 | £56.47 | £65.99 |
| Pumps/ Fans | £15.27 | £25.70 | £10.66 | £18.98 | £55.72 |
| Electricity for Lighting | £30.31 | £47.06 | £24.84 | £37.47 | £63.15 |
| Service Charges | £25.00 | £25.00 | £25.00 | £25.00 | £25.00 |
| Metering & Billing | £80.00 | £80.00 | £80.00 | £80.00 | £80.00 |
| Plant Maintenance | £110.00 | £110.00 | £110.00 | £110.00 | £110.00 |
| ASHP Maintenance | £20.00 | £20.00 | £20.00 | £20.00 | £20.00 |
| Total | £409.57 | £500.48 | £375.34 | £417.04 | £703.86 |
| Increase (%) | 1.25% | 3.92% | 2.52% | 1.18% | 2.01% |

TABLE 27 –YEARLY FUEL COSTS (ONLY) PER FLAT TYPE AS PER SAPs – BOILERS & ASHPs

Clarifications

- **Taken directly from SAP's*
- *Costs are based solely on desktop study with information available at the time of calculation*
- *The costs presented here are preliminary, as commensurate with the current stage of design, and therefore may be subject to change during detailed design of the development*
- *Inflation of utility costs have not been incorporated*
- *Final costs for maintenance / PPM and metering and billing are subject to appointment of specialist provider post construction.*
- *Consumption is based on SAP's calculations only.*

As it can be observed based on the SAP calculations the anticipated increase in energy costs due to the incorporation of the proposed technologies to reduce the carbon emissions have been kept to a minimum.

7.3 Heat Distribution Losses

In order to minimise the heat distribution losses enhanced insulation compared to building regulations and BS5422:2009 are proposed for the development. For the aboveground pipework it is proposed that the heating shall be insulated in accordance with the enhanced requirements of ECA & Y50 while the underground shall be Logstor Series 2 (Twin pipe for the 99% of the route). On the tables below are shown the distribution heat losses for the pipework compared to the building regulations requirements. For the calculation the following assumptions have been made; the average external temperature (in regards to underground pipework is 12°C for the underground pipework, an internal temperature of 25°C for pipework in the risers and ceiling voids and 20°C for the exposed internal pipework has been assumed.

| Below Ground Heat Distribution Losses | | | | | | | | | |
|---------------------------------------|-----------------|--------|---------------------------|---------------|-------------|---------------------------|---------------|-------------|---------------|
| Pipe Size (mm) | Soil cover (mm) | Length | Proposed | | | Building Regulations | | | Improvement % |
| | | | Insulation Thickness (mm) | Heat Loss W/m | Heat Loss W | Insulation Thickness (mm) | Heat Loss W/m | Heat Loss W | |
| 125 | 900 | 160 | 150 | 9.84 | 1574 | 30 | 21.67 | 3467 | 55% |
| 100 | 900 | 58 | 116 | 10.47 | 607 | 30 | 18.52 | 1074 | 43% |
| 65 | 600 | 43 | 83 | 9.61 | 413 | 25 | 15.31 | 658 | 37% |
| 100 | 600 | 40 | 116 | 10.55 | 422 | 30 | 18.52 | 741 | 43% |
| 80 | 600 | 50 | 92 | 10.67 | 534 | 25 | 17.20 | 860 | 38% |
| Total | | | | | 3550 | | | 6800 | 48% |

TABLE 28 – BELOW GROUND HEAT DISTRIBUTION LOSSES

| Risers- Ceilings Pipework Distribution Losses | | | | | | | | |
|---|--------|---------------------------|---------------|--------------|---------------------------|---------------|--------------|---------------|
| Pipe Size (mm) | Length | Proposed | | | Building Regulations | | | Improvement % |
| | | Insulation Thickness (mm) | Heat Loss W/m | Heat Loss kW | Insulation Thickness (mm) | Heat Loss W/m | Heat Loss kW | |
| 20 | 1548 | 25 | 6.64 | 10276 | 20 | 6.82 | 10552 | 20% |
| 25 | 1506 | 25 | 6.99 | 10520 | 20 | 8.08 | 12162 | 11% |
| 32 | 230 | 25 | 8.07 | 1856 | 20 | 9.13 | 2100 | 12% |
| 40 | 51 | 30 | 7.95 | 406 | 20 | 9.98 | 509 | 21% |
| 50 | 133 | 30 | 9.21 | 1224 | 25 | 10.25 | 1361 | 10% |
| 65 | 267 | 35 | 9.86 | 2634 | 25 | 12.10 | 3232 | 19% |
| 80 | 10 | 35 | 11.00 | 110 | 25 | 13.60 | 136 | 19% |
| 100 | 2 | 35 | 16.73 | 33 | 30 | 15.55 | 31 | 10% |
| Total | | | | 25277 | | | 30083 | 16% |

TABLE 29 – PIPEWORK IN RISERS & CEILINGS HEAT DISTRIBUTION LOSSES

| Combined Pipework Above Ground Distribution Losses | | | | | | | | |
|--|--------|---------------------------|---------------|-------------|---------------------------|---------------|-------------|---------------|
| Pipe Size (mm) | Length | Proposed | | | Building Regulations | | | Improvement % |
| | | Insulation Thickness (mm) | Heat Loss W/m | Heat Loss W | Insulation Thickness (mm) | Heat Loss W/m | Heat Loss W | |
| 100 | 2 | 35 | 16.73 | 33 | 30 | 18.52 | 37 | 10% |
| 80 | 10 | 35 | 13.90 | 139 | 25 | 17.20 | 172 | 19% |
| 65 | 75 | 35 | 12.45 | 934 | 25 | 15.31 | 1148 | 19% |
| Total | | | | 1,106 | | | 1,357 | 18% |

TABLE 30 – EXPOSED INTERNAL PIPEWORK HEAT DISTRIBUTION LOSSES

| Distribution Losses For Kidbrooke Station Square | | | | | | |
|--|-------------------|---------------|------|----------------------|---------------|------|
| Annual Load (kWh) | Proposed | | | Building Regulations | | |
| | Heat Losses (kWh) | Heat Loss (W) | Dlf | Heat Losses (kWh) | Heat Loss (W) | Dlf |
| 1736261 | 262,221 | 29,934 | 1.15 | 334,987 | 38,240 | 1.19 |

TABLE 31 – TOTAL HEAT DISTRIBUTION LOSSES

7.4 Photovoltaic Panels

It is proposed to install photovoltaic panels to provide further carbon reduction for the development. Hence the installation of PV panels of total output of 74.5kWp of monocrystalline PV panels with a nominal efficiency of 19.7% is proposed.

7.5 Be Green Summary

With the adoption of the “be green” measures as described above the development achieved the minimum 35% reduction in CO₂ emissions as demonstrated in the tables below:

| Unit Ref | Area | DER | Unit Emissions | No. Units | regulated Emissions |
|-----------------------------|----------------|-----------------------------------|-------------------------------|-----------|-------------------------------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | - | Tonnes CO ₂ /annum |
| Type 01 (1 Bed 2P) | 50 | 10.0 | 0.50 | 243 | 120.9 |
| Type 07 (3bed 5P) | 84 | 9.1 | 0.76 | 52 | 39.6 |
| Type 22 (studio) | 39 | 10.1 | 0.40 | 28 | 11.1 |
| Type 26 (2 bed 3P) | 62 | 8.2 | 0.51 | 287 | 144.9 |
| Type 25 (3 Bed 6P) | 135 | 10.2 | 1.38 | 9 | 12.4 |
| Be Green - Emissions | | | | | 329.0 |

TABLE 32 – BE GREEN - CO₂ REDUCTION FOR RESIDENTIAL OVER 2013 BUILDING REGULATION BASELINE – SAP10

| Target | Regulated tonnes CO ₂ savings per stage | Regulated percentage CO ₂ savings per stage |
|-----------------------------------|--|--|
| | Tonnes CO ₂ /annum | % |
| Be Lean Emissions | 63.2 | 11.6% |
| Be Clean Emissions | 0.0 | 0.0% |
| Be Green Emissions | 152.4 | 28.0% |
| Cumulative on site savings | 215.6 | 39.6% |

TABLE 33 - BE GREEN REDUCTIONS FOR RESIDENTIAL OVER 2013 BUILDING REGULATION BASELINE – SAP10




FIGURE 6 BE GREEN CARBON REDUCTION EMISSIONS FOR RESIDENTIAL UNITS–SAP10

| Unit Ref | Area | BER | Unit Emissions | Regulated | No. Units | Total Regulated Emissions |
|--|----------------|-----------------------------------|-------------------------------|-----------|-----------|-------------------------------|
| | m ² | KgCO ₂ /m ² | Tonnes CO ₂ /annum | | - | Tonnes CO ₂ /annum |
| Coffee shop | 104 | 42.2 | 4.4 | | 1 | 4.4 |
| Flexible use | 479 | 27.9 | 13.4 | | 1 | 13.4 |
| Gym | 104 | 69.1 | 7.2 | | 1 | 7.2 |
| Nursery | 262 | 13.5 | 3.5 | | 1 | 3.5 |
| Workshop | 1172 | 6.6 | 7.8 | | 1 | 7.8 |
| Total Be Lean Regulated Emissions | | | | | | 36.2 |

TABLE 34 - BE GREEN - CO₂ REDUCTION FOR THE NON-RESIDENTIAL SPACES OVER 2013 BUILDING REGULATION BASELINE–SAP10

| Target | Regulated savings per stage | tonnes CO ₂ | Regulated percentage savings per stage |
|-----------------------------------|-------------------------------|------------------------|--|
| | Tonnes CO ₂ /annum | | % |
| Be Lean Emissions | 8 | | 14.0% |
| Be Clean Emissions | 0 | | 0% |
| Be Green Emissions | 12 | | 22% |
| Cumulative on site savings | 8 | | 36.0% |

TABLE 35 - BE GREEN REDUCTIONS FOR THE NON-RESIDENTIAL SPACES OVER 2013 BUILDING REGULATION BASELINE –SAP10




FIGURE 7 BE GREEN CARBON REDUCTION EMISSIONS FOR NON-RESIDENTIAL SPACES – SAP10

| Target | Regulated tonnes CO ₂ savings per stage | Regulated percentage CO ₂ savings per stage |
|-----------------------------------|--|--|
| | Tonnes CO ₂ /annum | % |
| Be Lean Emissions | 71.1 | 11.8% |
| Be Clean Emissions | 0 | 0% |
| Be Green Emissions | 164.7 | 27.4% |
| Cumulative on site savings | 235.8 | 39.2 % |

TABLE 36 – TOTAL BE GREEN CARBON REDUCTION PERCENTAGE FOR KIDBROOKE STATION SQUARE DEVELOPMENT – SAP10

8 BREEAM

BREEAM UK NC 2014.

The commercial units within this development all fall under the category of 'Shell & Core' under BREEAM New Construction 2014. The assessment of the B1 Office space however, also takes account of an enhanced level of finish and significantly reduces the level of fit-out to be undertaken by the prospective tenants.

In order to address the current flexible nature of the commercial space, the units have been grouped by 'Use Class' and several assessments conducted based on each building type as follows:

- A1: Retail – shop
- A3: Retail – restaurant
- B1: Office – general office building
- D1: Other Buildings – community space

It is understood that the Royal Greenwich Local Plan: Core Strategy, Policy DH1: Design, highlights their vision to promote 'high quality design that positively contributes to the improvement of both built and natural environments across their development programme by avoiding negative impacts on the environment and aiming to meet their sustainability objectives.

The Royal Greenwich Local Plan: Core Strategy, Policy DH1: Design, requires non-domestic buildings in major developments to achieve a BREEAM rating of 'Excellent' with a minimum building score of 70%.

The BREEAM Pre-assessments of the commercial areas within the Kidbrooke Station Square development have undergone several reviews of the design. They have been recently revised based on the agreed design targets to provide a final indication of the BREEAM Rating that the developments commercial units are expected to achieve if proposed specifications and actions are implemented at the construction stage.

A final overall BREEAM Rating of 'high' Very Good has been demonstrated for the majority of building types with an excellent rating just being achieved for the B1 and D2 building types. The BREEAM Pre-assessment has been re-developed in cooperation with the design team to reflect the overall Building Ratings based on the current design information and desired targets.

The design approach taken throughout has been to enhance the sustainability performance standards as far as possible in key areas in line with BREEAM UK New Construction 2014 criterion and Royal Greenwich Core Strategy Policy DH1: Design.

Minimum sustainability performance standards and targets remain at the previous enhanced level of 'Outstanding' in all the required key sustainability areas within the assessment in order to demonstrate a high level of sustainable design. Key issues where minimum performance standards have been enhanced to improve the overall building score are as follows:

- Man03: Responsible Construction Practices – Outstanding performance level targeted
- Man04: Commissioning & handover – Outstanding performance level targeted
- Ene01: Reduction of Energy use and Carbon emissions – Outstanding performance level targeted
- Ene02: Energy Monitoring – Outstanding performance level targeted
- Wat02: Water Monitoring – Outstanding performance level targeted
- Mat03: Responsible Sourcing of Materials – Outstanding performance level targeted
- Wst03: Operational waste – Outstanding performance level targeted
- Le03: Minimising impact on existing site ecology – Outstanding performance level targeted

The current assessments reflect a BREEAM NC 2014 rating of 'Very Good' with scores exceeding the minimum requirement of 55% for A1, A1-A3 and D1 Use Classes. A BREEAM rating of Very Good is representative of the top 25% of all UK non-domestic buildings and a 'high' Very Good, as targeted on this development, is demonstrative of a positive move towards best practice.

Several challenges of achieving a rating of Excellent for Shell & Core buildings with sufficient buffer to maintain the rating throughout the construction stage have been encountered during the stage 2 design. This review has demonstrated that several credits are not currently achievable in several areas due to 'Shell & Core' design; feasibility of some issues at this stage; practicality, and a summary of some of these issues shown below:

- The pre-assessment reports and credit tracker clearly identify the credits targeted and those which will become a pre-requisite of achieving an excellent rating however, Kidbrooke Partnership LLP has indicated that the fit-out will be passed to a future tenant and as such, would be reticent to submit 'Shell and Core' BREEAM pre-assessment(s) with an excellent rating at the planning stage for units of a small size, thus placing the obligation on to a future SME tenant to achieve an excellent fit-out. The costs for this undertaking would fall to the tenant and could render the commercial space less affordable for a prospective SME's.
- Commissioning & Handover: Testing & inspecting of Building Fabric – The commercial units are being constructed to shell & core with limitations to internal finishes and therefore, it would not be technically feasible to achieve credit under this issue unless the building fabric is finished to such an extent to enable full thermographic survey and air pressure testing to be undertaken and any defects rectified in full prior to units being handed over.
- Daylighting – Credit for daylighting are assessed based on the building type and functions that apply. Based on the flexible nature of the commercial units, the daylighting has not been assessed at this stage as this will require more detailed information of internal layouts and use that are not generally available for a shell & core assessment.
- Cycle Storage – Credit for cycle storage has not been taken as the number of spaces required is calculated on the building type/function and number of staff/visitors for each building use. Due to the flexible nature of some of the commercial units, the number of spaces and area required would negatively impact on the open community streetscape and play space available.
- Cyclist facilities - Compliant cyclist facilities (showers, changing areas etc.) can be demonstrated where the shell and core building is designed to facilitate future installation of the compliant number and type of cyclist facilities by the tenant/owner-occupier through the provision of an appropriately sized and dedicated space in the base building, including either the installation of the appropriate services (for showers) or infrastructure to allow the future installation of the relevant services e.g. capped water supply, service or ventilation ducts, drainage etc. The number and type of facilities is based however, on the number of cycle spaces and building users for each building type and function.
- Functional Adaptability – This issue requires a building specific functional adaptation strategy to be undertaken at RIBA Stage 2 which includes recommendations for measures to be incorporated to facilitate the adoption of functional adaptation measures by RIBA Stage 4. Due to the flexible nature of some of the commercial space and that it is being constructed to shell & core, this issue has been considered as impractical at this stage.

The assessments of the A1, A1-A3 and D1 units reflect that a high rating of Very Good can be achieved and the current scores for each assessment also demonstrate a buffer of approx. 10% providing a reasonable safety margin to ensure that the rating of Very Good is achieved at the Post Construction stage. The assessment of the B1 units however, have only just achieved ratings of Excellent but have no flexibility within the scores to maintain a suitable buffer.

Generally a buffer of 10% is considered suitable to ensuring that the final rating is achieved at the Post Construction Stage as it is not always possible to claim every point targeted within the pre-assessment.

9 OVERHEATING

In order to mitigate the risks of overheating the following measures are to be adopted:

- Cold water pipe work is not to be installed in the same riser, or if unavoidable the distance between hot and cold services shall be maximised as far as possible. This is inclusive of horizontal services within ceiling voids.
- All distribution pipe work is to be insulated throughout to the requirements greater than that of the building regulations as NES Y50 (including the use of insulated pipe brackets).
- All floors between mechanical and electrical risers at each floor level are constructed with an open metal grid arrangement to aid the flow of air through the riser's vertical length, at the top the risers shall be vented to atmosphere with at least 2no weather proof vents. The open metal grid arrangement is to be able to support all required safe access for maintenance. The access door/s are to be fire rated to comply with building regulations and the fire strategy of the building, and ensure the riser can be used for ventilation of the pipe work and equipment.
- All natural AOV shafts / AOV windows shall have environmental and rain sensor control in addition to their fire and smoke control. The environment control will be connected to each corridor area to ensure the AOV opens when the communal corridor areas rise above 25oC.
- Where provided; mechanical AOV shafts shall be provided with an additional fan within the fan assembly for environmental ventilation, with floor louvres controls activated by environment controls connected to each corridor area to ensure the AOV opens when the communal corridor areas rise above 25°C.
- For mechanical or natural AOV systems, as part of the environmental controls permanent ventilation will be provided to the top of each stair core and above each stairs lobby door shall be provided with an adjustable fire damper / grille ventilating the stair core into the communal corridors ceiling void. The communal corridors ceiling will then be provided with grilles to provide fresh air make up as extracted by the AOV shaft.
- AOV environmental controls shall activate 1 hour in the AM and PM. Vents also should open automatically when triggered by dedicated thermostatic sensors in the communal areas.
- Communal corridor doors including fire doors are to be on magnetic door hold open controls to allow ventilation to all communal corridor areas. The control will have override for triggered by activation of the fire detection system and/or have fail safe operation. Alternatively louvers approved by the fire consultant will be provided at low levels at the doors to allow for air circulation
- Heat Interface Units (HIU's) will be mounted in the closest cupboard to the dwellings front door to minimise pipework length / heat loss within the dwellings hallway.

- HIU's shall be mounted within the dwellings utility cupboard and spaced off the wall by at least 25mm with the use of wood battens or spacers to promote air circulation behind the HIU (where allowable/ accepted by the HIU manufacturer).
- The utility cupboard will be provided with extract ventilation above the HIU.
- Communal area ceiling voids are to have means of natural ventilation to allow free movement of air in the ceiling voids throughout.

In addition to the above, dynamic overheating modelling has been carried out (please refer to overheating assessment report) for a sample of representative dwellings in line with the latest CIBSE Guidance TM52, TM59. Dynamic overheating simulations have been carried out for flats that have large glazing surfaces and predominantly facing south and west orientation as well as for communal corridors.

The overheating assessment demonstrated that the scheme complies with CIBSE TM 59 criteria when is assessed against Design Summer Year 1 (DSY1) weather file for London.

The simulations demonstrated that in order for the domestic spaces to pass CIBSE TM59 criteria windows facing east, south and west require a g-value of 0.4 with the inclusion of internal blinds. When detail design will be carried out more details can be provided.

Additional simulations for overheating against DSY2 & DSY3 weather files have also been carried out. The addition of any additional passive measures is considered to have a significant impact on the daylight factor of the habitable rooms.

Commercial spaces have large glazing surfaces hence it is important to minimise g-values. At this stage g-value of 0.4 has been suggested to minimise solar gains and ultimately the cooling demand.

9.1 Overheating Checklist

| Section 1 - Site Features affecting vulnerability to overheating | | Yes or No |
|---|---|--|
| Site Location | Urban - within central London ²⁹ or in a high density conurbation | Greenwich Borough. Inner London as defined by 2.2 of the London Plan Map. |
| | Peri-urban - on the suburban fringes of London ³⁰ | Greenwich Borough. Inner London as defined by 2.2 of the London Plan Map. |
| Air quality and/or Noise sensitivity - are any of the following in the vicinity of buildings? | Busy roads / A roads | Noise from A2 |
| | Railways / Overground / DLR | Yes |
| | Airport / Flight path | No |
| | Industrial uses / waste facility | No |
| Proposed building use | Will any buildings be occupied by vulnerable people (e.g. elderly, disabled, young children)? | 10% Disabled residential units. |
| | Are residents likely to be at home during the day (e.g. students)? | Low occupation. Predominantly young working professionals. Approx. 15% daytime occupation. |
| Dwelling aspect | Are there any single aspect units? | 272 (44%). |
| Glazing ratio | Is the glazing ratio (glazing: internal floor area) greater than 25%? | |
| | If yes, is this to allow acceptable levels of daylighting? | |
| Security - Are there any security issues that could limit opening of windows for ventilation? | Single Storey ground floor units | None. Duplex units at ground floor only. |
| | Vulnerable areas identified by the Police Architectural Liaison Officer | N/A |
| | Other | No single storey units at ground. Very few single storey units at first floor. |

²⁹ Urban - as defined in CIBSE Guide TM29. Broadly equivalent to Central Activities Zone and Inner London areas in Map 2.2 of the London Plan

³⁰ Peri-urban - as defined in CIBSE Guide TM29. Broadly equivalent to Outer London areas in Map2.2 of the London Plan

| Section 2 - Design features implemented to mitigate overheating risk | | Please respond |
|---|---|---|
| Landscaping | Will deciduous trees be provided for summer shading (to windows and pedestrian routes)? | Please refer to Standerwick 'Landscape Design Statement'. Wide range of trees provided around public and podium areas. |
| | Will green roofs be provided? | Please refer to Standerwick 'Landscape Design Statement'. Mixture of green and brown roofs. |
| | Will other green or blue infrastructure be provided around buildings for evaporative cooling? | Blue roof for water attenuation only |
| Materials | Have high albedo (light colour) materials been specified? | |
| Dwelling aspect | % of total units that are single aspect | 272 (44%). |
| | % single aspect with N / NE / NW orientation | NW - 24% |
| | % single aspect with E orientation | 0% |
| | % single aspect with S / SE / SW orientation | SE - 19%, SW - 1% |
| | % single aspect with W orientation | 15% |
| Glazing ratio - What is the glazing ratio (glazing: internal floor area) on each façade? | N / NE / NW | Block A 29.9% |
| | E | Block B 19.5% |
| | S / SE / SW | Block C 22.2% |
| | W | Block D 16.4% |
| | | Block E 20.0% |
| | Block F 19.9% | |
| | Block G 17.4% | |
| | Block H 29.8% | |
| Daylighting | What is the average daylight factor range? | |
| Windows opening | Are windows openable? | Varies per window type. |
| | What is the percentage of openable area for the windows? | Varies per window type. Please refer to typical GHA bay studies. |
| Windows opening - What is the extent of the opening | Fully openable | Restricted to 100mm. Can be unlocked for purge. |
| | Limited (e.g. for security, safety, wind loading reasons) | Restricted for safety. |
| Security | Where there are security issued (e.g. ground floor flats) has an alternative night time natural ventilation method been provided (e.g. ventilation grates)? | No ground floor flats. Very low percentage of single storey units at second floor. No alternative natural vent method yet proposed. |

| | | |
|---|--|----------------------------|
| Shading | Is there external shading? | No |
| | Is there internal shading? | No |
| Glazing Specification | Is there any solar control glazing? | Yes |
| Ventilation - What is the ventilation strategy? | Natural - background | No |
| | Natural - purge | Yes |
| | Mechanical - background (e.g. MVHR) | Yes (MVHR) |
| | Mechanical - purge | No |
| | What is the average design air change rate | As Per Approved Document F |
| Heating System | Is communal heating present? | Yes |
| | What is the flow/ return temperature? | 70-40 |
| | Have horizontal pipe runs been minimised? | Yes |
| | Do the specification include insulation levels in line with the London Heat Network Manual ³¹ | Yes |

³¹ http://www.londonheatmap.org.uk/Content/uploaded/documents/LHNM_Mnaua12014Low.pdf

Single Aspect Units

LP policy 3.5 refers to design guidance in the Mayor’s Housing SPG (March 2016). The SPG Standard 29 indicates that developments should minimise the number of single aspect units. It does not specify a prescribed level. What it does indicate is that where the number of single aspect units are provided, they adequately address issues such as noise, ventilation and daylight.

The KSS development responds to the site constraints so that the massing and orientation of buildings is designed to maximise access to natural light, provide privacy and security to residents and promote a social community. The aspect of units has evolved positively following a series of RBG Pre-app meetings, following which all single facing north facing units were removed and the number of dual aspect units increased from 54-56% (to 346 units). None of the 3-bed units are single aspect.

The Noise Chapter of the ES (para 14.6.5) finds that, with the proposed mitigation measures, there would be no operational phase noise impact to any of the residential rooms within the site: “With the glazing and ventilation specified installed. SLR anticipate that there would be no noise impact internal to sensitive rooms at the Site”.

The Energy Strategy (pg.13) explains that all habitable rooms will benefit from mechanical ventilation to assist with heat recovery. Purge ventilation will also be provided by opening windows.

Finally, on daylight, the 17 April 2019 amendment submission included the re-planning of 91 of the homes to improved internal daylight/sunlight. These were all 1B2P homes located in Buildings A, D, G, H & F. As a result of the changes, 88% of the proposed habitable rooms now meet or exceed the Average Daylight Factor recommended by BRE, an improvement from 80%, thereby offering good levels of daylight.

The design of the development therefore accords with the Development Plan and the Mayor's Housing SPG in this respect.

Passive Design Measures

Balcony locations across blocks B-G have been designed to provide solar shade to L/K/D spaces in units below. With increased shading provided to private amenity areas in Blocks A+H using inset balconies. Apartment layouts have been designed to focus on providing good levels of daylight, with 1444 (88%) of the proposed habitable rooms meeting or exceeding the levels of Average Daylight Factor (ADF) recommended by BRE. Additionally, the vast majority of the rooms have been designed in accordance with the Room Depth Criterion (RDC) where applicable, and 77% of the assessed rooms will also see good levels of sky visibility.

Additional passive measure, for example external fixed or operable shading to control solar gain would decrease the percentage of habitable rooms achieving acceptable levels of ADF.

The fixing and operation of blinds to be used shall not lead to the reduction of the required free area of the windows. The specification of a product can only be detailed during detail design when the full specifications of the windows are available. Additionally, a dwelling operation manual including the overheating mitigation strategy shall be provided to all occupants.

Also please note that the majority of the habitable rooms under DY2 & DSY3 are still passing the overheating criteria (94.3% and 73.45% respectively as per the overheating report)

10 LONDON ZERO CARBON HOMES

“Zero carbon” homes applies to homes forming part of the mayor’s development application (10 or more residential units) where the residential element of the application needs to achieve at least a 35 per cent reduction in regulated carbon emissions (beyond Part L 2013) on-site. The remaining regulated carbon dioxide emissions, to 100 per cent, are to be off-set through a cash in lieu contribution to the relevant borough to secure delivery of carbon dioxide savings elsewhere (in line with policy 5.2E).

The “zero carbon” target as defined above will be implemented for Stage 1 schemes received by the Mayor on or after the 1st October 2016 here detailed.

To summarise, the emission reduction targets the GLA will apply to applications are as follows:

- *Stage 1 schemes received by the Mayor up until 30 September 2016 – 35% below Part L 2013 for both residential and commercial development.*
- *Stage 1 schemes received by the Mayor on or after the 1st October 2016– Zero carbon (as defined in section 5.2 of the Housing SPG) for residential development and 35% below Part L 2013 for commercial development*

The criterion for Zero Carbon homes applications includes:

- *Strategic Applications (Development of 150 residential units or more, over 30 meters or are located on Green Belt or Metropolitan Open Lan).*
- *Major Development Applications (10 dwellings or more)*

The technical implementation of this policy should be in line with this guidance document. The mayor’s Housing Standard’s Viability Assessment assumed a carbon off-set price of £60 per tonnes of carbon dioxide for a period of 30 years. Where the borough applies a carbon dioxide off-set price of £60 per tonnes, it is not considered necessary for boroughs to carry out a further viability assessment of the policy approach.

Policy 5.2B’s emission reduction targets for non-domestic uses were intended to ensure a smooth trajectory towards a zero carbon standard and the upcoming requirement for ‘Nearly Zero Energy Buildings’ by 2020 however at this moment in time the GLA will only continue to require that non-domestic developments seek to achieve a 35 per cent reduction against Part L 2013.

In the light of the above considerations, the Zero Carbon Homes policy does apply to the development as it is a construction of more than 10 homes deeming it to be a major development bearing in mind that the carbon off set payment applies only to the residential units. Table 38 below shows the offset cost to be paid over 30 years.

| | Regulated Emissions | Cost for tonnes of CO₂ emissions | Cumulative savings for off-set payments over 30 years |
|--|-------------------------------|--|--|
| | Tonnes CO ₂ /annum | £/tonnes CO ₂ per 30 years | |
| London Plan Policy 5.2B - zero carbon - | 329 | £1,800.00 | £592,167 |

TABLE 37 - OFF SET PAYMENTS ACCORDING THE LONDON PLAN POLICY 5.2B

In accordance with London Plan 5.2 any shortfall in achieving the carbon dioxide reduction on-site might be provided off-site, but only in cases where there is an alternative proposal identified and delivery is certain, or where funding can be pooled to support specific carbon dioxide reduction projects or programmes. In this specific case no specific proposal has been identified and therefore a cash in lieu contribution to Greenwich has been offered to secure delivery of carbon dioxide savings elsewhere.

11 CONCLUSION

A series of energy efficiency and best practice measures has been adopted in order to meet the London Plan and Royal Borough of Greenwich requirements, which in summary are:

- Enhanced building fabric as described within this document (see Table 4)
- Adoption of an Air Source Heat Pump system and heat network as described in this report
- Photovoltaic panels of 74.5kWp capacity

This report has demonstrated how the development proposals make the fullest contribution to minimising carbon dioxide emissions in accordance taking into account the new GLA guidance and the revised emissions factors included in SAP10 with the following energy hierarchy:

1. Be lean: use less energy – fabric improvements, highly efficient systems and lighting
2. Be clean: supply energy efficiently – N/A
3. Be green: use renewable energy in the form of Air Source Heat Pumps and Photovoltaic Panels

11.1 Overall CO₂ emissions

Table 38 shows the final carbon emissions for the development site and the percentage of improvement over the baseline emissions 2013 (SAP10).

| Target | Regulated tonnes CO ₂ savings per stage | Regulated percentage CO ₂ savings per stage |
|-----------------------------------|--|--|
| | Tonnes CO ₂ /annum | % |
| Be Lean Emissions | 71.1 | 11.8% |
| Be Clean Emissions | 0 | 0% |
| Be Green Emissions | 164.7 | 27.4% |
| Cumulative on site savings | 235.8 | 39.2 % |

TABLE 38 - FINAL CO₂ REDUCTION FOR KIDBROOKE STATION SQUARE DEVELOPMENT

Signed:

Dimitrios Anthopoulos MSc BEng (Hons)

Principal Mechanical Engineer, for and on behalf of Calfordseaden LLP

NOTES:

All outputs are based on initial design stage SAP/SBEM assessments for the development and need to be confirmed by final design SAP/SBEM calculations once they have been completed for the development.


SAPs have been based on Part L 2013 Building Regulations.

Examination of roof areas and photovoltaic module specification with manufacturer's details and requirements.

12 APPENDICES

1. Energy Centre Layout
2. Heat Network Layout
3. Photovoltaic Array Layout
4. ASHP Data Sheet

- NOTES:
1. ALL DIMENSIONS IN MILLIMETRES, UNLESS OTHERWISE STATED.
 2. THIS DRAWING TO BE READ IN CONJUNCTION WITH THE SPECIFICATION AND ALL OTHER CONTRACT DRAWINGS.




| | | | | |
|-----|-------------|----------|------|------|
| 02 | Preliminary | 30/07/19 | DA | DA |
| REV | DESCRIPTION | DATE | INIT | CHKD |



Client
 NHG
 Project
Kidbrooke Station Square
 Title
Energy Centre Ground Floor
 Scale: **1 : 50** Date: **30/07/19** Drawn By: **DA** Checked By: **DA** Project No: **L180038** Drawing No: **CS-M-SK-200** Revision: **02**
 St John's House 1a Knoll Rise Orpington Kent BR6 0JX
 01689 888222 orpington@calfordseaden.com
 calfordseaden LLP is a Limited Liability Partnership Registered in England & Wales number OC315838
 ORPINGTON ■ LONDON ■ BIRMINGHAM ■ SOUTHDOWN ■ WINCHESTER ■ CAMBRIDGE calfordseaden.com

- NOTES:
1. ALL DIMENSIONS IN MILLIMETRES, UNLESS OTHERWISE STATED.
 2. THIS DRAWING TO BE READ IN CONJUNCTION WITH THE SPECIFICATION AND ALL OTHER CONTRACT DRAWINGS.



| | | | | |
|-----|-------------|----------|------|------|
| 02 | Preliminary | 30/07/19 | DA | DA |
| REV | DESCRIPTION | DATE | INIT | CHKD |




Client
NHG
 Project
Kidbrooke Station Square
 Title
Energy Centre First Floor
 Scale: **1 : 50** Date: **30/07/19** Drawn By: **DA** Checked By: **DA** Project No: **L180038** Drawing No: **CS-M-SK-201** Revision: **02**
 St John's House 1a Knoll Rise Orpington Kent BR6 0JX
 01689 888222 orpington@calfordseaden.com
 calfordseaden LLP is a Limited Liability Partnership Registered in England & Wales number OC315838
 ORPINGTON ■ LONDON ■ BIRMINGHAM ■ SOUTHWEST ■ WINCHESTER ■ CAMBRIDGE calfordseaden.com

General Notes:

- 1. ALL DIMENSIONS IN MILLIMETERS, UNLESS OTHERWISE STATED.
- 2. THIS DRAWING TO BE READ IN CONJUNCTION WITH THE SPECIFICATION AND ALL OTHER CONTRACT DRAWINGS.
- 3. NOT ALL INDIVIDUAL CONNECTIONS & BRANCH ARE SHOWN.

Legend

- HTG PRIMARY DISTRIBUTION
- HTG SECONDARY DISTRIBUTION



| REV | DESCRIPTION | DATE | INIT | CHKD |
|-----|-------------|------|------|------|
| | | | | |

Client
Notting Hill Genesis
Project
Kidbrooke Estate
Title
Block H Energy Centre Ground Floor Layout

Scale: 1:50@A1 Date: 01.11.17 Drawn By: JB Checked By: LC Project No: L180038 Drawing No: M_DR_001 Revision:

King's Head House King's Head Yard Borough High Street London SE1 1NA
020 7940 3200 london@calfordseaden.com
calfordseaden LLP is a Limited Liability Partnership Registered in England & Wales number OC315838
ORPINGTON | LONDON | BIRMINGHAM | CAMBRIDGE | SOUTHEAST-ON-SEA | WINCHESTER

calfordseaden

Notting Hill Genesis










FOR INFORMATION


calfordseaden.com

General Notes:

1. ALL DIMENSIONS IN MILLIMETERS, UNLESS OTHERWISE STATED.
2. THIS DRAWING TO BE READ IN CONJUNCTION WITH THE SPECIFICATION AND ALL OTHER CONTRACT DRAWINGS.
3. PV ARRAYS TO BE CO-ORDINATED WITH SVP'S AND ANY ROOF OBSTACLES.
4. WHERE NECESSARY, ROOF LEVEL AC AND DC CABLES ARE TO CONTAINED/ROUTED IN HD GALVANISED 50mm TRAY SUPPORTED OFF FINISHED ROOF USING ZIPP CLAMPS (FINAL ROUTES TO BE DETERMINED ON SITE).
5. ANGLE OF PV TILES FROM HORIZONTAL TO BE 10° MINIMUM FOR SELF CLEANING PURPOSES.
6. INVERTORS AND DC AND AC ISOLATORS TO BE LOCATED WITH RISERS.
7. PRECISE PANEL LOCATIONS & CONFIGURATION ON ROOF SUBJECT TO SURVEY AT POINT OF INSTALLATION.
8. PV PANELS WILL BE SOUTH ORIENTATED WITH A TILT ANGLE OF 10°.
9. PROPOSAL PROVIDES 74.5kWp FOR ALL BLOCKS IN ACCORDANCE WITH THE ENERGY STRATEGY.

Legend

-  PV DISTRIBUTION BOARD
-  SP&N ISOLATOR
-  DC ISOLATOR
-  TP&N ISOLATOR
-  PV GENERATION METER
-  PHOTOVOLTAIC PANEL
-  PROPOSED DC CABLE TRAY ROUTE
-  MCB CIRCUIT BREAKER
-  ACCESS AREA
SPACE ALLOCATED FOR AC PROVISION FOR COMMERCIAL UNIT IF REQUIRED




| C3 | Updated Block H | 27.06.19 | AC | DA |
|-----|------------------------|----------|------|------|
| O2 | Updated Blocks D/G & H | 14.06.19 | JB | DB |
| O1 | Issued for Information | 21.03.19 | JB | DA |
| REV | DESCRIPTION | DATE | INIT | CHKD |

| 27.06.19 | AC | DA |
|----------|------|------|
| 14.06.19 | JB | DB |
| 21.03.19 | JB | DA |
| DATE | INIT | CHKD |




Client
Notting Hill Genesis
Project
Kidbrooke Estate
Title
Sitewide PV Layout



Scale Date Drawn By Checked By Project No: Drawing No: Revision

1:500@A1 01.11.17 JB LC L180038 E_SK_101 03

FOR INFORMATION



Changes for the Better

HOT WATER HEAT PUMP

for a greener tomorrow



MODEL

CAHV-P500YA-HPB(-BS)

DATA BOOK

2nd edition

Contents

I Product Specifications

- 1. Specifications 2
- 2. External Dimensions 3
- 3. Center of Gravity 4
- 4. Electrical Wiring Diagrams 5
- 5. Accessories 8
- 6. Optional parts 8
 - (1) Remote controller PAR-W21MAA
 - (2) Representative-water temperature sensor TW-TH16

II Product Data

- 1. Capacity tables 10
 - (1) Correction by temperature
 - (2) Correction by relative humidity
 - (3) Correction by water flow rate
 - (4) Water pressure drop
 - (5) Operation temperature range
- 2. Sound pressure levels 14
- 3. Vibration levels 15

III Installation

- 1. Selecting the Installation Site 16
 - (1) Installation conditions
 - (2) Installation space requirements
- 2. Installation of unit 20
 - (1) Position of anti-vibration pads
- 3. Removing the metal plates and saddles around the compressor 21
- 4. Installing the unit in a snow area 22

IV System Design

- 1. Water pipe installation 23
 - (1) Caution for water pipe installation
 - (2) Installing the water pipes
 - (3) Water pipe hole size and location
- 2. Ensuring enough water in the water circuit 27
 - (1) Required amount of water
 - (2) Calculating the required amount of water in the water circuit
- 3. Inlet/Outlet pipe connection size and material 27

V Wiring Design

- 1. Electrical wiring installation 28
 - (1) Wiring of main power supply and equipment capacity
 - (2) Cable connections
- 2. System configurations 30
 - (1) Types of control cables
 - (2) System Configuration

VI Controller


- 1. PAR-W21MAA specifications 31

I | Product Specifications

1. Specifications

| | | | |
|---|----------------------------|---|---|
| Model | | CAHV-P500YA-HPB | |
| Power Source | | 3-phase 4-wire 380-400-415V 50/60Hz | |
| Capacity *1 | kW | | 45 |
| | kcal/h | | 38700 |
| | BTU/h | | 153540 |
| | Power input | kW | 12.9 |
| | Current input | A | 21.78-20.69-19.94 |
| COP (kW / kW) | | 3.49 | |
| Capacity *2 | kW | | 45 |
| | kcal/h | | 38700 |
| | BTU/h | | 153540 |
| | Power input | kW | 25.6 |
| | Current input | A | 43.17-41.01-39.53 |
| COP (kW / kW) | | 1.76 | |
| Maximum current input *3 | | A | 57.77-54.88-52.90 |
| Water pressure drop *1 | | 12.9kPa (1.87psi) | |
| Temp range | Outlet water temp *4 | | 25~70°C 77~158°F |
| | Outdoor temp *4 | D.B | -20~40°C -4~104°F |
| Circulating water volume range | | 7.5 m³/h-15.0m³/h | |
| Sound Pressure level (measured in anechoic room) *1 | | dB (A) | 59 |
| Sound Pressure level (measured in anechoic room) *3 | | dB (A) | 63 |
| Diameter of water pipe | Inlet | mm (in.) | 38.1 (Rc 1 1/2") screw |
| | Outlet | mm (in.) | 38.1 (Rc 1 1/2") screw |
| External finish | | Acrylic painted steel plate <MUNSELL 5Y 8/1 or similar> | |
| External dimension H × W × D | | mm in. | 1710 (without legs 1650) × 1978 × 759 67.3 (without legs 65.0) × 77.9 × 29.9 |
| Net weight | | kg (lb) | 526 (1160) |
| Accessories | | Y strainer Rc 1 1/2 | |
| Design Pressure | R407C | MPa | 3.85 |
| | Water | MPa | 1.0 |
| Drawing | Wiring | KC94G723X01 | |
| | External | KC94G195X01 | |
| Heat exchanger | Water side | stainless steel plate and copper brazing | |
| | Air side | Plate fin and copper tube | |
| Compressor | Type | Inverter scroll hermetic compressor | |
| | Maker | MITSUBISHI ELECTRIC CORPORATION | |
| | Starting method | Inverter | |
| | Motor output | kW | 7.5 × 2 |
| | Case heater | kW | 0.045 × 2 |
| | Lubricant | MEL32 | |
| FAN | Air flow rate | m³/min | 185 × 2 |
| | | L/s | 3083 × 2 |
| | | cfm | 6532 × 2 |
| | External static press *5 | 0Pa, 60Pa (0mmH ₂ O/6.1mmH ₂ O) | |
| | Type × Quantity | Propeller fan × 2 | |
| | Control, Driving mechanism | Inverter-control, Direct-driven by motor | |
| Motor output | kW | 0.46 × 2 | |
| HIC circuit (HIC:Heat inter-Changer) | | Copper pipe | |
| Protection | High pressure protection | High pres. Sensor & High pres. Switch at 3.85MPa (643psi) | |
| | Inverter circuit | Over-heat protection, Over current protection | |
| | Compressor | Over-heat protection | |
| | Fan motor | Thermal switch | |
| Defrosting method | | Auto-defrost mode (Reversed refrigerant circle) | |
| Refrigerant | Type × original charge | R407C × 5.5(kg) × 2 | |
| | Control | LEV and HIC circuit | |

- *1 Under Nominal heating conditions at outdoor temp, 7°C DB/6°C WB(44.6°F DB/42.8°F WB) outlet water temp 45°C(113°F), inlet water temp 40°C(104°F)
 *2 Under Heating conditions at outdoor temp, 7°C DB/6°C WB(44.6°F DB/42.8°F WB), outlet water temp 70°C (158°F)
 *3 Under Heating conditions at outdoor temp, 7°C DB/6°C WB(44.6°F DB/42.8°F WB) when this unit is set to capacity priority mode by non-voltage B contact
 *5 Dip SW on the unit control board need to be changed.
 * Due to continuing improvement, the above specifications may be subject to change without notice.
 * Please don't use the steel material for the water piping material.
 * Please always make water circulate or pull out the circulation water completely when not using it.
 * Please do not use groundwater and well water.
 * Install the unit in an environment where the wet bulb temp will not exceed 32°C (89.6°F).
 * The water circuit must use the closed circuit.




Unit converter
 kcal = kW × 860
 BTU/h = kW × 3,412
 cfm = m³/min × 35.31
 lb = kg/0.4536

2. External Dimensions





- CAHV-P500YA-HPB(-BS)

Unit: mm

Note.
Please install the drain pan because defrosting water or dew condensation water drops from holes on the unit base.




<Accessory>
• Y type strainer 1-1/2 <Bronze> . . . 1 piece
(This is for the water piping.
Please install it near the water inlet.)



3. Center of Gravity


- CAHV-P500YA-HPB(-BS)

Unit: mm



4. Electrical Wiring Diagrams

• CAHV-P500YA-HPB(-BS)




Note1. Single-dotted lines indicate field wiring.
 Note2. The symbols of the field connecting terminals are as follows.
 Note3. Fan terminals have a locking function. Press the tab in the middle of the terminals to remove them. Check that the terminals are securely locked in place after insertion.
 Note4. Selects either Drain pan signal or Defrost signal by SW2 and SW3 settings. (Item code 1056)

Note5. Selects either Water temperature setting input signal or Capacity control input signal by SW2 and SW3 settings. (Item code 1051)

Due to continuing improvement, the above specifications may be subject to change without notice.

• CAHV-P500YA-HPB(-BS)



SUB BOX

Note1: Single-dotted lines indicate field wiring.
 Note2: Faston terminals have a locking function.
 Pass the tab in the middle of the terminals to remove them.
 Check that the terminals are securely locked in place after insertion.

• CAHV-P500YA-HPB(-BS)

Symbol explanation


| Symbol | explanation |
|------------|---|
| CH | Crankcase heater (for heating the compressor) |
| CT12 | |
| CT22 | Ac current sensor |
| CT3 | |
| C100 | Capacitor (Electrolysis) |
| DCL | DC reactor |
| F01 | |
| F02 | |
| F03 | |
| F04 | Fuse |
| F05 | |
| F06 | |
| LEV1 | Electronic expansion valve (Main circuit) |
| LEV2 | Electronic expansion valve (Injection) |
| M | Fan motor |
| MS | Compressor motor |
| R1 | Electrical resistance |
| R5 | |
| SV1 | Solenoid valve (Injection circuit) |
| SV2 | Solenoid valve (Hot gas circuit) |
| THHS | IGBT temperature |
| ZZ1 | Function setting connector |
| Z1S4 | 4-way valve |
| 63HS | High pressure sensor |
| 63H1 | High pressure switch |
| 63LS | Low pressure sensor |
| 72C | Electromagnetic relay (Inverter main circuit) |
| TH1-4 | |
| TH9-11 | Thermistor |
| TH14 | |
| TH5-8 | Thermistor |
| TH12,13 | |
| <ELB1,2,3> | Earth leakage breaker |
| <F2,3> | Fuse |
| <MP> | Pump motor |
| <51P> | Overcurrent relay (Pump) |
| <52P> | Electromagnetic contactor (Pump) |

Note

- The broken lines indicate the optional parts, field-supplied parts, and field work.
- Make sure to connect a pump interlock contact.
A short-circuit may cause abnormal stop or malfunctions.
- Operation signals can be received from the remote controller or through the dry contact. The temperature setting can be changed by a signal received through the dry contact or by using the schedule setting.
- Leave a space of at least 5 cm between the low voltage external wiring (no-voltage contact input and remote controller wiring) and wiring of 100V or greater. Do not place them in the same conduit tube or cable tray as this will damage the circuit board.
- When cable tray is used for the control cable wiring, use a separate cable tray for the following wiring.
Using the same cable tray may cause malfunctions and damage to the unit.
(a) Optional remote controller wiring
(b) No-voltage contact input wiring
(c) No-voltage contact output wiring
(d) Remote water temperature setting
- Use a contact that takes 12VDC 5mA for no-voltage contact input.

5. Accessories

- CAHV-P500YA-HPB(-BS)




(A) Install the strainer at the water pipe inlet.


6. Optional parts

- (1) Remote controller PAR-W21MAA

Refer to Chapter VI "Controller", section 1. "PAR-W21MAA specifications".



Panel closed



Panel open

(2) Representative-water temperature sensor TW-TH16

(2)-1 Required parts for installing a representative-water temperature sensor

- Ⓐ Representative-water temperature sensor
- Ⓑ Cable for connecting between the sensor and the unit*
- Ⓒ Cable terminal for connecting to the sensor and the unit terminal block*
(Terminals for M4 screws x 4)*

* Ⓐ and Ⓑ are field-supplied.


Cable specifications

| | |
|--------|--|
| Size | 2-core, 1.25 mm ² or larger |
| Type | CVVS or CPEVS |
| Length | 20m |


(2)-2 Installing a representative-water temperature sensor

As shown in the figures at right, install the sensor at the merged part of water pipes or the load-side tank. The sensor can be installed in either the vertical or the horizontal position.

When installing the sensor in the horizontal position, make sure to place the cable-access-hole side down.




Vertical installation



Horizontal installation

(2)-3 Wiring for a representative-water temperature sensor

As shown in the figures below, connect the cable to the representative-water temperature sensor and the terminal block in the unit control box.




On the unit side, connect the sensor cable to the terminals T1 and T2 in the terminal block 12P in the unit control box.

Connect the shielded cable to the ground terminal.

On the sensor side, as shown in the figure at right, run the cable through ④, ③, and ②, attach the field-supplied terminals for M4 screws to the cable, and then connect the terminals to the screws ⑤ and ⑥ (terminal A and B).

Cut the shielded cable and leave it unconnected. (On the unit side, the shielded cable should be connected to the ground terminal already.)

Tighten the tightening screw ④, and caulk the gap between the tightening screw ④ and cable ① to prevent water leakage.



Enlarged view of area A: Cable installation

II Product Data

1. Capacity tables

(1) Correction by temperature

• CAHV-P500YA-HPB(-BS)

(1)-1 Efficiency Priority Mode

• Capacity



| | | Intake air temperature °C | | | | | | | | | | | | | | | |
|-----------------------------|----|---------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | -20 | -15 | -10 | -7 | -5 | 0 | 2 | 5 | 7 | 10 | 16 | 20 | 25 | 30 | 35 | 40 |
| Outlet water temperature °C | 35 | - | - | 40.3 | 42.2 | 42.4 | 42.7 | 42.8 | 43.5 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 |
| | 45 | 32.0 | 37.4 | 40.6 | 42.4 | 42.6 | 42.9 | 43.0 | 43.5 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 |
| | 55 | 32.2 | 37.7 | 40.8 | 42.7 | 42.8 | 43.1 | 43.2 | 43.6 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 |
| | 60 | 32.2 | 37.8 | 40.9 | 42.8 | 42.9 | 43.2 | 43.3 | 43.7 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 |
| | 65 | 32.2 | 37.9 | 41.0 | 42.9 | 43.0 | 43.3 | 43.4 | 43.7 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 |
| | 70 | - | - | 41.1 | 43.0 | 43.1 | 43.4 | 43.5 | 43.7 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 | 45.0 |

This table shows the capacity when the relative humidity is 85%.
The intake wet-bulb temperature is fixed to 32°C when the intake dry-bulb temperature is 35°C or higher.

• Power input

| | | Intake air temperature °C | | | | | | | | | | | | | | | |
|-----------------------------|----|---------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | -20 | -15 | -10 | -7 | -5 | 0 | 2 | 5 | 7 | 10 | 16 | 20 | 25 | 30 | 35 | 40 |
| Outlet water temperature °C | 35 | - | - | 17.0 | 16.9 | 16.2 | 14.7 | 14.2 | 12.0 | 10.9 | 9.82 | 8.20 | 7.40 | 6.60 | 6.30 | 6.02 | 5.77 |
| | 45 | 18.4 | 19.4 | 19.4 | 19.5 | 18.7 | 17.0 | 16.4 | 14.2 | 12.9 | 11.9 | 10.1 | 9.08 | 8.05 | 7.73 | 7.44 | 7.17 |
| | 55 | 21.2 | 22.5 | 22.7 | 22.8 | 22.0 | 20.1 | 19.5 | 17.5 | 16.5 | 15.2 | 13.2 | 12.1 | 11.0 | 10.3 | 9.75 | 9.24 |
| | 60 | 22.9 | 24.5 | 24.8 | 25.0 | 24.1 | 22.1 | 21.4 | 19.1 | 17.8 | 16.6 | 14.7 | 13.6 | 12.4 | 11.6 | 10.8 | 10.2 |
| | 65 | 24.9 | 26.8 | 27.3 | 27.6 | 26.7 | 24.6 | 23.9 | 22.2 | 21.3 | 19.6 | 16.9 | 15.4 | 14.0 | 13.0 | 12.1 | 11.4 |
| | 70 | - | - | 30.2 | 30.8 | 29.8 | 27.6 | 26.9 | 25.7 | 25.6 | 23.9 | 19.9 | 18.0 | 16.0 | 14.8 | 13.8 | 12.9 |

This table shows the power input when the relative humidity is 85%.
The intake wet-bulb temperature is fixed to 32°C when the intake dry-bulb temperature is 35°C or higher.



(1)-2 Capacity Priority Mode

• Capacity



| | | Intake air temperature °C | | | | | | | | | | | | | | | |
|-----------------------------|----|---------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | -20 | -15 | -10 | -7 | -5 | 0 | 2 | 5 | 7 | 10 | 16 | 20 | 25 | 30 | 35 | 40 |
| Outlet water temperature °C | 35 | - | - | 40.3 | 42.2 | 42.4 | 42.7 | 45.4 | 49.6 | 63.4 | 65.9 | 71.3 | 73.9 | 75.4 | 73.0 | 70.5 | 68.0 |
| | 45 | 32.0 | 37.4 | 40.6 | 42.4 | 42.6 | 42.9 | 45.0 | 49.1 | 63.2 | 65.6 | 70.4 | 73.0 | 74.8 | 72.2 | 69.6 | 67.0 |
| | 55 | 32.2 | 37.7 | 40.8 | 42.7 | 42.8 | 43.1 | 44.5 | 48.8 | 62.8 | 65.9 | 69.6 | 71.3 | 71.0 | 69.2 | 67.5 | 65.7 |
| | 60 | 32.2 | 37.8 | 40.9 | 42.8 | 42.9 | 43.2 | 44.1 | 48.6 | 61.5 | 64.8 | 68.6 | 69.7 | 69.4 | 68.1 | 66.8 | 65.5 |
| | 65 | 32.2 | 37.9 | 41.0 | 42.9 | 43.0 | 43.3 | 43.7 | 48.5 | 60.1 | 63.1 | 67.6 | 68.7 | 67.8 | 66.9 | 66.1 | 65.2 |
| | 70 | - | - | 41.1 | 43.0 | 43.1 | 43.4 | 43.5 | 48.3 | 58.7 | 61.3 | 65.8 | 66.7 | 66.1 | 65.7 | 65.4 | 65.0 |

This table shows the capacity when the relative humidity is 85%.
The intake wet-bulb temperature is fixed to 32°C when the intake dry-bulb temperature is 35°C or higher.

• Power input


| | | Intake air temperature °C | | | | | | | | | | | | | | | |
|-----------------------------|----|---------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | -20 | -15 | -10 | -7 | -5 | 0 | 2 | 5 | 7 | 10 | 16 | 20 | 25 | 30 | 35 | 40 |
| Outlet water temperature °C | 35 | - | - | 17.0 | 16.9 | 16.2 | 14.7 | 15.6 | 15.2 | 17.7 | 17.0 | 16.2 | 15.3 | 13.9 | 12.7 | 11.6 | 10.8 |
| | 45 | 18.4 | 19.4 | 19.4 | 19.5 | 18.7 | 17.0 | 17.8 | 17.6 | 20.9 | 20.2 | 19.2 | 18.1 | 16.6 | 14.6 | 12.9 | 11.8 |
| | 55 | 21.2 | 22.5 | 22.7 | 22.8 | 22.0 | 20.1 | 20.8 | 21.2 | 25.6 | 25.3 | 23.9 | 22.2 | 19.5 | 17.4 | 15.6 | 14.1 |
| | 60 | 22.9 | 24.5 | 24.8 | 25.0 | 24.1 | 22.1 | 22.6 | 23.4 | 27.9 | 27.9 | 26.6 | 24.3 | 21.3 | 19.0 | 17.2 | 15.6 |
| | 65 | 24.9 | 26.8 | 27.3 | 27.6 | 26.7 | 24.6 | 24.8 | 25.8 | 30.1 | 30.2 | 29.6 | 27.0 | 23.2 | 20.9 | 19.0 | 17.4 |
| | 70 | - | - | 30.2 | 30.8 | 29.8 | 27.6 | 27.5 | 28.6 | 32.6 | 32.7 | 32.5 | 29.5 | 25.2 | 23.1 | 21.3 | 19.7 |

This table shows the power input when the relative humidity is 85%.
The intake wet-bulb temperature is fixed to 32°C when the intake dry-bulb temperature is 35°C or higher.




(2) Correction by relative humidity

- CAHV-P500YA-HPB(-BS)




(3) Correction by water flow rate

- CAHV-P500YA-HPB(-BS)




*Conditions Outdoor temperature 0°C
Intake water temperature 65°C
Frequency of compressor 100Hz



*Conditions Outdoor temperature 0°C
Intake water temperature 50°C
Frequency of compressor 100Hz

(4) Water pressure drop


- CAHV-P500YA-HPB(-BS)



(5) Operation temperature range

- CAHV-P500YA-HPB(-BS)


Heating



2. Sound pressure levels


Measurement condition

- CAHV-P500YA-HPB(-BS)




Sound Pressure Level: 59.0 / 63.0 dB (COP Priority Mode / Capacity Priority Mode)

Operation condition... Spring, Autumn: Outdoor temp.: 16°CDB/12°CWB, Inlet water temp.: 40°C, Outlet water temp.: 45°C
 Winter: Outdoor temp.: 7°CDB/6°CWB, Inlet water temp.: 65°C, Outlet water temp.: 70°C



3. Vibration levels

- CAHV-P500YA-HPB(-BS)



| Model | Vibration Levels [dB] |
|----------------------|-----------------------|
| CAHV-P500YA-HPB(-BS) | 47 or less |

III | Installation

1. Selecting the Installation Site

(1) Installation conditions

Select the installation site in consultation with the client.

Select a site to install the outdoor unit that meets the following conditions:


- The unit will not be subject to heat from other heat sources.
- The noise from the unit will not be a problem.
- The unit will not be exposed to strong winds.
- Water from the unit can be drained properly.
- The space requirements (specified on page 17) are met.

(1)-1. Providing protection against winds


Using the figures at right as a reference, provide adequate protection against winds.

A unit installed alone is vulnerable to strong winds. Select the installation site carefully to minimize the effect of winds.

When installing a unit in a place where the wind always blows from the same direction, install the unit so that the outlet faces away from the direction of the wind.



- Install the outdoor unit in a place where it is not exposed to direct wind, such as behind a building.



- Install the outdoor unit so that the outlet/inlet faces away from the wind.

(1)-2. Cold Climate Installation

Observe the following when installing the units in areas where snow or strong winds prevail.

- Avoid direct exposure to rain, winds, and snow.
- When deciding the high of the unit stand for snow damage prevention, consider the snow accumulation.
- There is a possibility that an icicle may form under the unit stand. Consider this when installing the unit on the roof for this may injure person or the property.
- If the units are installed in the direct line of rain, winds, or snow, install the optional snow hood (on both the discharge and suction ducts). Use a snow net or snow fence as necessary to protect the unit.
- Install the unit on a base approximately twice as high as the expected snowfall.
- If the unit is continuously operated for a long time with the outside air temperature below the freezing point, install a heater at the base of the unit to prevent the water from freezing at the unit bottom.


(2) Installation space requirements

(2)-1. Single unit installation

Secure enough space around the unit as shown in the figures below.



<Unit: mm>

(2)-1-1. Walls around the unit do not exceed the height limit.






(A) Walls are lower than the unit's height.

(2)-1-2. There is a wall above the unit.




(2)-1-3. One or more of the walls around the unit are taller than the maximum allowable height h.



(A) Walls are lower than the unit's height.

(2)-1-4. Water pipe installation



Leave a space of at least 500 between the unit and the water pipe if it is not possible to install the unit on a raised foundation. (SEE in the figure.)

(2)-2. Grouped and side-by-side installation


When multiple units are installed adjacent to each other, allow enough space for air circulation and a walk way between groups of units as shown in the figures below.

* Leave both sides of each group of units open.

As with individual installation, if the wall height exceeds the height limit, widen the space in the front and the back of a given group of units by the amount that exceeds the limit (labeled h in the figure).


<Unit: mm>

(2)-2-1. Side-by-side installation




(2)-2-2. Face-to-face installation

- There are walls in the back and the front of a given group of units.





- There is a wall on one side.





(2)-2-3. Combination of face-to-face and side-by-side installations

- There are walls in the back and the front of a given group of units.
- There is a wall on one side and either the front or the back of a given group of unit.



(2)-2-4. Water pipe installation



If the product width (labeled A in the figure) times the number of units that are installed side by side exceeds 6 m, leave a space of 1000 mm between each block. Each block is defined as a group of units that fit within 6 m.

If the product depth (labeled B in the figure) times the number of units that are installed in rows exceeds 6 m, leave a space of 1000 mm between each block. Each block is defined as a group of units that fit within 6 m.

(2)-3. Required airflow rate for the unit

Unit: m³/min

| Model | Standard airflow rate | Minimum airflow rate | Allowable external static pressure (Unit: Pa) |
|----------------------|-----------------------|----------------------|---|
| CAHV-P500YA-HPB(-BS) | 370 | 333 | 10 |

2. Installation of unit

Units should be installed only by personnel certified by Mitsubishi Electric.

- Fix unit tightly with bolts so that unit will not fall down due to earthquakes or strong winds.
- Use concrete or an angle bracket as the foundation of unit.
- Vibration may be transmitted to the installation section and noise and vibration may be generated from the floor and walls, depending on the installation conditions. Therefore, provide ample vibrationproofing (cushion pads, cushion frame, etc.).
- Build the foundation in such way that the corner of the installation leg is securely supported as shown in the figure. When using a rubber isolating cushion, please ensure it is large enough to cover the entire width of each of the unit's legs. If the corners are not firmly seated, the installation feet may be bent.
- The projecting length of the anchor bolt should be less than 30 mm.
- Hole-in anchor bolts are not compatible with this product. However, if fixing brackets are mounted on the 4 locations of the unit attachment part, hole-in anchor bolts can be used.
- The detachable leg can be removed at the site.
- Detaching the detachable leg
Loosen the three screws to detach the detachable leg (Two each in the front and back).
If the base leg finish is damaged when detaching, be sure to repair at the site.


Warning:

- **Be sure to install unit in a place strong enough to withstand its weight.**
Any lack of strength may cause unit to fall down, resulting in a personal injury.
- **Have installation work in order to protect against strong winds and earthquakes.**
Any installation deficiency may cause unit to fall down, resulting in a personal injury.


When building the foundation, give full attention to the floor strength, drain water disposal <during operation, drain water flows out of the unit>, and piping and wiring routes.

Precautions when routing the pipes and wires below the unit (Without detachable leg)

When routing the pipes and wires below the unit, be sure that the foundation and base work do not block the base through-holes. Also make sure the foundation is at least 100 mm high so that the piping can pass under the unit.




(1) Position of anti-vibration pads



3. Removing the metal plates and saddles around the compressor



The metal plates and saddles are used only for transportation. Remove the metal plates and saddles before operating the unit to keep the unit from vibrating excessively.



4. Installing the unit in a snow area

In snowy areas, sufficient protection against snow and winds should be provided to ensure proper operation.


Even in other areas, appropriate measures should be taken to minimize the effects of winds and snow to ensure normal operation.

To ensure proper operation, install a field-supplied outlet/inlet duct if the unit is directly exposed to wind, rain, or snow and is operated in the cooling mode with the outside air temperature of 10°C or below.

(Note)

- Install the unit on a base approximately twice as high as the expected snowfall. The base must be made of angle steel or something to let snow and wind slip through the structure. The base width must not exceed the unit size, otherwise snow will accumulate on the base.
- Install the unit so that the outlet/inlet faces away from the wind.

• CAHV-P500YA-HPB(-BS)




(Note)

1. Install the unit so that the outlet/inlet faces away from the wind. Secure enough space around the unit to avoid a short cycle.
2. Do not install the unit in a place where snow may fall from the roof. Also, remove the snow on the unit before it accumulates.
3. Refer to the figure above when installing the base on site.

IV System Design

1. Water pipe installation

(1) Caution for water pipe installation



| | |
|-----------------------------------|--|
| ① Union joints/flange joints etc. | Required to allow for a replacement of equipment |
| ② Thermometer | Required to check the performance and monitor the operation of the units. |
| ③ Water pressure gauge | Recommended for checking the operation status. |
| ④ Valve | Required to allow for a replacement or cleaning of the flow adjuster. |
| ⑤ Flexible joint | Recommended to prevent the noise and vibration from the pump from being transmitted. |
| ⑥ Drain pipe | Install the drain pipe with a downward inclination of between 1/100 and 1/200. To prevent drain water from freezing in winter, install the drain pipe as steep an angle as practically possible and minimize the straight line. For cold climate installation, take an appropriate measure (e.g., drain heater) to prevent the drain water from freezing. |
| ⑦ Pump | Use a pump that is large enough to compensate for the total water pressure loss and supply sufficient water to the unit. |
| ⑧ Air vent valve | Install air venting valves to the places where air can accumulate. Automatic air vent valves (such as ⑧') are effective. |
| ⑨ Expansion tank | Install an expansion tank to accommodate expanded water and to supply water. |
| ⑩ Water pipe | Use pipes that allow for easy air purging, and provide adequate insulation. |
| ⑪ Drain valve | Install drain valves so that water can be drained for servicing. |
| ⑫ Strainer | Install a strainer near the unit to keep foreign materials from entering the water-side head exchanger (supplied). |
| ⑬ Flow switch | Required to protect the unit. |

(1)-1 Notes on pipe corrosion

Water processing and water quality control

When the circulating water quality is poor, the water heat exchanger can develop scales, leading to a reduction in heat-exchange power and possible corrosion of the heat exchanger. Please pay careful attention to water processing and water quality control when installing the water circulation system.

- Removal of foreign objects or impurities within the pipes.
During installation, be careful that foreign objects, such as welding fragments, sealant particles, or rust, do not enter the pipes.
- Water Quality Processing

(1)-1-1 Depending on the quality of water used, the heat exchanger may become corroded or scaled up. We recommend regular water quality processing.

Water circulation systems using open heat storage tanks are particularly prone to corrosion.

When using an open-type heat storage tank, install a water-to-water heat exchanger, and use a closed-loop circuit on the air conditioner side. If a water supply tank is installed, keep contact with air to a minimum, and keep the level of dissolved oxygen in the water no higher than 1 mg/l.

(1)-1-2 Water quality standard

| Items | | Lower mid-range temperature water system Water Temp. ≤ 60°C | | Higher mid-range temperature water system Water Temp. > 60°C | | Tendency | |
|------------------------|---|--|-----------------------------|---|-----------------------------|-----------|---------------|
| | | Recirculating water | Make-up water | Recirculating water | Make-up water | Corrosive | Scale-forming |
| Standard items | pH (25 °C) | 7.0 ~ 8.0 | 7.0 ~ 8.0 | 7.0 ~ 8.0 | 7.0 ~ 8.0 | ○ | ○ |
| | Electric conductivity (mS/m) (25 °C) (µs/cm) (25 °C) | 30 or less [300 or less] | 30 or less [300 or less] | 30 or less [300 or less] | 30 or less [300 or less] | ○ | ○ |
| | Chloride ion (mg Cl/l) | 50 or less | 50 or less | 30 or less | 30 or less | ○ | |
| | Sulfate ion (mg SO ₄ ²⁻ /l) | 50 or less | 50 or less | 30 or less | 30 or less | ○ | |
| | Acid consumption (pH4.8) (mg CaCO ₃ /l) | 50 or less | 50 or less | 50 or less | 50 or less | | ○ |
| | Total hardness (mg CaCO ₃ /l) | 70 or less | 70 or less | 70 or less | 70 or less | | ○ |
| | Calcium hardness (mg CaCO ₃ /l) | 50 or less | 50 or less | 50 or less | 50 or less | | ○ |
| Reference items | Ionic silica (mg SiO ₂ /l) | 30 or less | 30 or less | 30 or less | 30 or less | | ○ |
| | Iron (mg Fe/l) | 1.0 or less | 0.3 or less | 1.0 or less | 0.3 or less | ○ | ○ |
| | Copper (mg Cu/l) | 1.0 or less | 1.0 or less | 1.0 or less | 1.0 or less | ○ | |
| | Sulfide ion (mg S ²⁻ /l) | Not to be detected | Not to be detected | Not to be detected | Not to be detected | ○ | |
| | Ammonium ion (mg NH ₄ ⁺ /l) | 0.3 or less | 0.1 or less | 0.1 or less | 0.1 or less | ○ | |
| | Residual chlorine (mg Cl/l) | 0.25 or less | 0.3 or less | 0.1 or less | 0.3 or less | ○ | |
| | Free carbon dioxide (mg CO ₂ /l) | 0.4 or less | 4.0 or less | 0.4 or less | 4.0 or less | ○ | |
| Ryzner stability index | — | — | — | — | ○ | ○ | |

Reference: Guideline of Water Quality for Refrigeration and Air Conditioning Equipment. (JRA GL02E-1994)

(1)-1-3 Please consult with a water quality control specialist about water quality control methods and water quality calculations before using anti-corrosive solutions for water quality management.


(1)-1-4 When replacing a previously installed air conditioning device (even when only the heat exchanger is being replaced), first conduct a water quality analysis and check for possible corrosion. Corrosion can occur in water systems even if there has been no prior signs of corrosion. If the water quality level has dropped, please adjust water quality sufficiently before replacing the unit.

(1)-1-5 Suspended solids in the water

Sand, pebbles, suspended solids, and corrosion products in water can damage the heating surface of the heat exchanger and cause corrosion. Install a good quality strainer (20 mesh or better) at the inlet of the unit to filter out suspended solids.

Removing foreign substances from the water system

Consider installing a settlement tank or a bypass strainer to remove foreign substances from the water system. Select a strainer capable of handling two to three percent of the circulating water. The figure below shows a sample system with a bypass strainer.



(1)-1-6 Connecting pipes made from different materials

If different types of metals are placed in direct contact with each other, the contact surface will corrode. Install an insulating material between pipes that are made of different materials to keep them out of direct contact with each other.

(2) Installing the water pipes

(2)-1 Installing the strainer


Install the supplied strainer on the inlet water pipe near the unit to filter out suspended solids and prevent clogging or corrosion of the heat exchanger.

Install the strainer in a way that allows for easy access for cleaning, and instruct the user to clean it regularly.

Operating the units with a clogged strainer may cause the units to make an abnormal stop.

Select a location to install a strainer, taking into consideration the installation angle, insulation thickness, and maintenance space.

* The dimensions given below indicate the amount of space necessary when screwing in a Y-shaped strainer.




(2)-2 Installing a flow switch

Install a flow switch that meets the following specifications on the water pipe.
Connect the flow switch to the flow switch contact on the unit.

Minimum flow rate= 7.5 m³/h (125 L/min)

Unit usage range (water flow rate): 7.5 - 15.0 m³/h

(3) Water pipe hole size and location



2. Ensuring enough water in the water circuit

(1) Required amount of water

If the amount of water in the water circuit (circulating water circuit) is insufficient, the unit operation hours may become shorter or the amount of water temperature change to be controlled may become extremely large. Also, the defrost operation during the heating mode may not function properly. Refer to the table below for the minimum amount of water required in the circuit. If the water pipe is too short to keep enough amount of water, install a cushion tank in the water pipe to ensure enough amount of water.

| Model | Minimum amount of water (ℓ) |
|----------------------|-----------------------------|
| CAHV-P500YA-HPB(-BS) | 360 |

(2) Calculating the required amount of water in the water circuit

The required amount of water in the water circuit can be obtained from the following formula.

(Required amount of water in the water circuit) = (Amount of water that can be held in the water pipe) + (Amount of water that can be held in the heat source unit) + (Amount of water that can be held in the load-side unit)

The amount of water that can be held per meter of the water pipe (ℓ/m)

| Pipe size | | | | | |
|------------|----------|--------------|--------------|----------|--------------|
| 3/4B (20A) | 1B (25A) | 1 1/4B (32A) | 1 1/2B (40A) | 2B (50A) | 1 1/2B (65A) |
| 0.37 | 0.60 | 0.99 | 1.36 | 2.20 | 3.62 |

The amount of water that can be held in the heat source unit (ℓ)

| |
|----------------------|
| CAHV-P500YA-HPB(-BS) |
| 14 |

3. Inlet/Outlet pipe connection size and material

The table below shows the inlet/outlet pipe connection size.

Inlet/Outlet pipe connection size

| Model | Inlet pipe connection | Outlet pipe connection |
|----------------------|--------------------------------|-------------------------------|
| CAHV-P500YA-HPB(-BS) | R1 - 1/2 Female screw <SUS304> | R1 - 1/2 Female screw<SUS304> |


V | Wiring Design

1. Electrical wiring installation

(1) Wiring of main power supply and equipment capacity

Schematic Drawing of Wiring (Example)

- (A): Switch (Breakers for wiring and current leakage)
- (B): Breakers for current leakage
- (C): Outdoor unit
- (D): Pull box
- (E): Indoor unit



Thickness of wire for main power supply, capacities of the switch and system impedance

| Model | Minimum wire thickness (mm ²) | | | Breaker for current leakage | Local switch (A) | | Breaker for wiring (NFB) (A) | Max. Permissible System Impedance |
|-----------------|---|--------|--------|-----------------------------|------------------|------|------------------------------|-----------------------------------|
| | Main cable | Branch | Ground | | Capacity | Fuse | | |
| CAHV-P500YA-HPB | 25 | - | 25 | 75A 100mA 0.1sec. or less | 75 | 75 | 75 | 0.28 Ω |

1. Use dedicated power supplies for the unit. Ensure each units are wired individually.
2. Bear in mind ambient conditions (ambient temperature, direct sunlight, rain water, etc.) when proceeding with the wiring and connections.
3. The wire size is the minimum value for metal conduit wiring. If the voltage drops, use a wire that is one rank thicker in diameter.
Make sure the power-supply voltage does not drop more than 10%.
4. Specific wiring requirements should adhere to the wiring regulations of the region.
5. Power supply cords of parts of appliances for outdoor use shall not be lighter than polychloroprene sheathed flexible cord (design 60245 IEC57).
6. A switch with at least 3 mm contact separation in each pole shall be provided by the Air Conditioner installer.
7. Do not install a phase advancing capacitor on the motor. Doing so may damage the capacitor and result in fire. The figure in the parentheses indicates the capacity necessary when the "Maximum capacity operation" setting is selected.

⚠ Warning:

- Be sure to use specified wires for connections and ensure no external force is imparted to terminal connections. If connections are not fixed firmly, heating or fire may result.
- Be sure to use the appropriate type of overcurrent protection switch. Note that generated overcurrent may include some amount of direct current.

⚠ Caution:

- Some installation sites may require attachment of an earth leakage breaker for the inverter. If no earth leakage breaker is installed, there is a danger of electric shock.
- Do not use anything other than a breaker and fuse with the correct capacity. Using a fuse or wire of too large capacity may cause malfunction or fire.

Note:

- This device is intended for the connection to a power supply system with a maximum permissible system impedance shown in the above table at the interface point (power service box) of the user's supply.
- The user must ensure that this device is connected only to a power supply system which fulfils the requirement above.
If necessary, the user can ask the public power supply company for the system impedance at the interface point.
- This equipment complies with IEC 61000-3-12 provided that the short-circuit power SSC is greater than or equal to SSC (*2) at the interface point between the user's supply and the public system. It is the responsibility of the installer or user of the equipment to ensure, by consultation with the distribution network operator if necessary, that the equipment is connected only to a supply with a short-circuit power SSC greater than or equal to SSC (*2).


S_{sc} (*2)

| Model | S _{sc} (MVA) |
|-----------------|-----------------------|
| CAHV-P500YA-HPB | 4.11 |

(2) Cable connections

(2)-1 Terminal Block Arrangement


To remove the front panel of the control box, unscrew the four screws and pull the panel forward and then down.



Important: Power supply cables larger than 25 mm² in diameter are not connectable to the power supply terminal block (TB2). Use a pull box to connect them.

(2)-2 Installing the conduit tube

- Punch out the knockout hole for wire routing at the bottom of the front panel with a hammer.
- When putting wires through knockout holes without protecting them with a conduit tube, deburr the holes and protect the wires with protective tape.
- If damage from animals is a concern, use a conduit tube to narrow the opening.



2. System configurations

(1) Types of control cables


| | | | |
|---------------------------|------------------------------|--------------------------|---|
| Control cable wiring | Remote controller cable | Size | 0.3 - 1.25 mm ² (Max. 200 m total) |
| | | Recommended cable types | CVV |
| | M-NET cable between units *1 | Size | More than 1.25 mm ² (Max. 120 m total) |
| | | Recommended cable types | Shielding wire CVVS, CPEVS or MVVS |
| | External input wire size | Min. 0.3 mm ² | |
| External output wire size | 1.25 mm ² | | |

*1. Use a CVVS or CPEVS cable (Max. total length of 200 m) if there is a source of electrical interference near by (e.g., factory) or the total length of control wiring exceeds 120 m.

(2) System Configuration


(2)-1 Individual system

- Each unit is operated individually by connecting a dry contact switch/relay to each unit.



(2)-2 Multiple system (2-16 units)

- A group of unit that consists of one main unit and up to 15 sub units is operated collectively by connecting a representative water temperature sensor and a dry contact switch/relay to the main unit.



VI | Controller

1. PAR-W21MAA specifications

| Item | Description | Operations | Display |
|-----------------------------------|--|------------|---------|
| ON/OFF | Runs and stops the operation of a group of units | ○ | ○ |
| Operation mode switching | Switches between Hot Water / Heating / Heating ECO / Anti-freeze / Cooling * Available operation modes vary depending on the unit to be connected. * Switching limit setting can be made via a remote controller. | ○ | ○ |
| Water temperature setting | Temperature can be set within the ranges below. (in increments of 1°C or 1°F) Hot Water 30°C ~ 70°C Heating 30°C ~ 45°C Heating ECO 30°C ~ 45°C Anti-freeze 10°C ~ 45°C Cooling 10°C ~ 30°C * The settable range varies depending on the unit to be connected. | ○ | ○ |
| Water temperature display | 10°C ~ 90°C (in increments of 1°C or 1°F) * The settable range varies depending on the unit to be connected. | × | ○ |
| Permit / Prohibit local operation | Individually prohibits operations of each local remote control function :ON/OFF, Operation modes, water temperature setting, Circulating water replacement warning reset. * Upper level controller may not be connected depending on the unit to be connected. | × | ○ |
| Weekly scheduler | ON / OFF / Water temperature setting can be done up to 6 times one day in the week. (in increments of a minute) | ○ | ○ |
| Error | When an error is currently occurring on a unit, the afflicted unit and the error code are displayed. | × | ○ |
| Self check (Error history) | Searches the latest error history by pressing the CHECK button twice. | ○ | ○ |
| Test run | Enables the Test run mode by pressing the TEST button twice. * Test run mode is not available depending on the unit to be connected. | ○ | ○ |
| LANGUAGE setting | The language on the dot matrix LCD can be changed. (Seven languages) English/German/Spanish/Russian/Italian/French/Swedish | ○ | ○ |
| Operation locking function | Remote controller operation can be locked or unlocked. • All-switch locking • Locking except ON/OFF switch | ○ | ○ |

DATA BOOK CAHV-P500YA-HPB(-BS)



for a greener tomorrow

Eco Changes is the Mitsubishi Electric Group's environmental statement, and expresses the Group's stance on environmental management. Through a wide range of businesses, we are helping contribute to the realization of a sustainable society.

⚠ Warning

- Do not use refrigerant other than the type indicated in the manuals provided with the unit and on the nameplate.
 - Doing so may cause the unit or pipes to burst, or result in explosion or fire during use, during repair, or at the time of disposal of the unit.
 - It may also be in violation of applicable laws.
 - MITSUBISHI ELECTRIC CORPORATION cannot be held responsible for malfunctions or accidents resulting from the use of the wrong type of refrigerant.

mitsubishi electric corporation

HEAD OFFICE: TOKYO BLDG., 2-7-3, MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN
<http://Global.MitsubishiElectric.com>